

X1/X3-EVC Series User Manual

7.2 kW - 22 kW (Home Edition)







SolaX Power Network Technology (Zhejiang) Co., Ltd.

ADD.: No. 288, Shizhu Road, Tonglu Economic Development Zone, Tonglu City, Zhejiang Province, 310000 P.R. CHINA.

TEL.: +86 (0) 571-56260011 **E-mail:** info@solaxpower.com

Copyright Declaration

The copyright of this manual belongs to SolaX Power Network Technology (Zhejiang) Co., Ltd. Any corporation or individual should not plagiarize, partially or fully copy it (including software, etc.), and no reproduction or distribution of it in any form or by any means shall be allowed. All rights reserved. SolaX Power Network Technology (Zhejiang) Co., Ltd. reserves the right of final interpretation.

Change History

Changes between document versions are cumulative. The latest version contains all updates made in previous versions.

Version 07 (Dec. 26, 2022)

Updated 2.1 Appropriate Usage (Added a note)
Updated 5.5 CT Connection (Modified notes about CT connection)

Version 06 (Oct. 27, 2022)

Updated 2.3 Explanation of Symbols (Added a note)
Updated 4.2 Security Protection (Modified Multiple Protection part)

Version 05 (Sep. 8, 2022)

Updated 2.3 Explanation of Symbols (Modified the TUV mark Logo) Updated 7 APP Setting (Modified the descriptions and updated the screenshots)

Version 04 (May 18, 2022)

Updated 3.1 Basic Features (Modified the description)
Updated 4.2 Security Protection (Modified Multiple Protection part)
Updated 5.4 Installation Steps (Modified the strip length of PE wire)
Updated 6.3 Charging Modes (Modified the descriptions and diagrams)
Updated 7 APP Setting (Modified the Wi-Fi Connection part)

Version 03 (Mar. 31, 2022)

Updated 6.2 Start-up Patterns (Added the card activation description)
Updated 6.3 Charging Modes (Added a note to GREEN/ECO mode)
Updated 7 APP Setting (Modified the descriptions and updated the screenshots)
Updated 8.1 Troubleshooting (Modified the solution part)

Version 02 (Feb. 25, 2022)

Updated 2.3 Explanation of Symbols (Added the TUV mark) Updated 4.1 General Data (Updated the details in the table)

Version 01 (Feb. 10, 2022)

Updated 4.1 General Data (Updated Communication Info) Updated 5.2 Packing List (Added RFID card) Updated 5.4 Installation Steps (Added PIN definition in SETP 6)

Version 00 (Jan. 18, 2022)

Initial release

Contents

1 No	ote on this Manual	03
1.1	Scope of Validity	03
1.2	Target Group	03
1.3	Symbols Used	03
2 Sa	fety	04
2.1	Appropriate Usage	04
2.2	Important Safety Instructions	05
2.3	Explanation of Symbols	06
3 In	troduction	07
3.1	Basic Features	07
3.2	Dimension	08
3.3	Product Description	10
4 Te	chnical Data	11
4.1	General Data	11
4.2	Security Protection	12
5 In:	stallation	13
5.1	Check for Transport Damage	13
5.2	Packing List	13
5.3	Installation Precaution	14
5.4	Installation Steps	15
5.5	CT Connection	24
5.6	Run the EV-Charger	26
6 Op	peration Method	27
6.1	States	27
6.2	Start-up Patterns	27
6.3	Charging Modes	29
6	.3.1 GREEN Mode	30
6	.3.2 ECO Mode	30
6	.3.3 FAST Mode	31

Contents Notes on this Manual

6	.3.4 Smart Boost	32
6	.3.5 Timer Boost	32
6.4	Dynamic Load Balance	33
7 Ap	op Setting	34
8 Tro	oubleshooting	46
8.1	Troubleshooting	46
8.2	Routine Maintenance	49
9 De	ecommissioning	50
9.1	Dismantling the EV-Charger	50
9.2	Packaging	50
9.3	Storage and Transportation	50
9.4	Disposing of the EV-Charger	50
10 D	Disclaimer	51

1 Notes on this Manual

1.1 Scope of Validity

This manual is an integral part of the X1/X3-EVC Series EV-Charger. It describes the assembly, installation, commissioning, maintenance and failure of the product. Please read it carefully before operating.

X1-EVC-7.2K(SXH)	X3-EVC-11K(SXH)	X3-EVC-22K(SXH)
X1-EVC-7.2K(PXH)	X3-EVC-11K(PXH)	X3-EVC-22K(PXH)

Note:

"X1" means single-phase, "X3" means three-phase.

"EVC" means "EV-Charger".

"7.2K" means 7.2 kW, "11K" means 11 kW, "22K" means 22 kW.

"S": Socket Type, only socket outlet, "P": Plug Type (also called Connector Type), with charging cable and connector.

"X": without LCD screen.

"H": home edition.

Keep this manual at where it is accessible all the time.

1.2 Target Group

This manual is for qualified electricians. The tasks described in this manual can only be performed by qualified electricians.

1.3 Symbols Used

The following types of safety instructions and general information appear in this document as described below:



DANGER!

"Danger" indicates a hazardous situation which, if not avoided, will result in death or serious injury.



WARNING!

"Warning" indicates a hazardous situation which, if not avoided, could result in death or serious injury.



CAUTION!

"Caution" indicates a hazardous situation which, if not avoided, could result in minor or moderate injury.



NOTE!

"Note" provides tips that are valuable for the optimal operation of your product.


^{*} Warranty Registration Form

Safety Safety


2 Safety

2.1 Appropriate Usage

The series are AC EV charger, intended to be installed in a fixed location and connected to the AC supply.



Communication with CT/Meter



Communication with Inverter



NOTE!

If the system has zero injection requirement, the EV-charger must communicate with the inverter. For the details, please refer to https://kb.solaxpower.com/data/detail/ff80808184a409170184c63a76b20027.html.

2.2 Important Safety Instructions

DANGER!

- •Danger to life due to output and input high voltages in this device!
- All work must be carried out by qualified electrician who has knowledge of and experience in dealing with electrical installations.



- •The device is not to be used by children or persons with reduced physical sensory or mental capabilities, or lack of experience and knowledge, unless they have been given supervision or instruction.
- •Children should be supervised to ensure that they do not play with the device.



CAUTION!

- · Danger of burn injuries due to hot enclosure parts!
- During operation, the EV-Charger may become hot.



CAUTION!

Incorrect operation or misuse may result in:

- Injury or death to the operator or third parties.
- Damage to the device and other property of the operator.
- Inefficient operation of the device.



WARNING!

Risk of electric shock!

- Prior to the application, please read this section carefully to ensure correct and safe application. Please keep the user manual properly.
- · Use only accessories recommended. Otherwise may result in a risk of fire, electric shock, or injury to person.
- · Make sure that existing wiring is in good condition and that wire is not undersized.
- Do not disassemble any parts of the EV-Charger which are not mentioned in installation guide. It contains no user-serviceable parts. See Warranty for instructions on obtaining service. Attempting to maintain the EV-Charger by yourself may result in a risk of electric shock or fire and will void your warranty.
- · Keep away from flammable, explosive materials to avoid fire disaster.
- The installation place should be away from humid or corrosive substance.

Safety Introduction

- Authorized service personnel must use insulated tools when installing or working with this equipment.
- Do not use the EV-Charger in case the device has defects, cracks, abrasion, bare leakage and so on. Please contact the working staff in case of above conditions.
- In case any emergency condition happens, please press the EMERGENCY STOP button immediately, cut off all input and output power supply.
- During charging, the electric vehicle is not allowed to drive. Charging only when the electric vehicle stays still. For hybrid car, charging only when switching the engine off.

2.3 Explanation of Symbols

This section gives an explanation of all the symbols shown on the EV-Charger type label.

Symbol	Explanation
CE	CE mark. The EV-Charger complies with the requirements of the applicable CE guidelines.
TÜVRholsland CERTIFIED Typa Appares Series Series Suppliered Ince Suppliered I	TUV certification.
A	Danger of high voltages. Danger to life due to high voltages in the EV-Charger!
\triangle	Danger. Risk of electric shock!
A	The EV-Charger can not be disposed together with household waste. Used electrical devices must be collected separately and recycled in an environmentally responsible manner. Ensure that you return your used device to your dealer or obtain information regarding a local, authorised collection and disposal system.
	The EV-Charger can be recycled.

Note: The table is only used for the description of symbols which may be used on the EV-charger. Please be subject to the actual symbols on the device.

3 Introduction

3.1 Basic Features


Thanks for purchasing with the series EV-Charger. The EV-Charger can be used for charging your electric vehicle in your home. Also you can choose single or three phase with plug or socket type, you can consult our salesmen for specific details. The features of the series are listed as below.

- Plug or socket outlet selectable
- Integrated current failure monitoring (30mA AC & 6mA DC)
- Integrated with PEN protection and no earth rod
- Encrypted communication based on TLS
- Indoor and outdoor easy installation
- Form an intelligent photovoltaic, storage and EV charging energy system through the communication between the smart EV charger and SolaX inverter
- Capable with 100% green energy generated from your solar generation
- Multiple work modes to fit different situations
- Integrated RFID function
- Remote setting and monitoring with APP and website
- Smart dynamic load balance control
- Set timers to reduce your cost during peak and valley price


Introduction

3.2 Dimension

Socket Type




> Plug Type (Connector Type)



Introduction Technical Data

3.3 Product Description



Object	Name	Description
Α	Button	EMERGENCY STOP: Press in emergency, the EV-Charger will stop operating.
В		MODE SELECTION: Press to select certain mode.
С	Charging connector base	Socket outlet (for Socket Type)/Connector holder (for Plug Type)
D		Operating status: The corresponding mode light will be on when operating.
Е	LED indicator	Complete: When the light is on the EV-Charger completes charging or is in idle state.
F		Timer: When the light is on, the boost mode is running.
G		Fault: The red light will be on when error occurs.
Н	Card swiping position	Swipe card here.
I	Connector	INPUT: For AC input connection.
J	Connector	COM: For communication connection.

4 Technical Data

4.1 General Data

Model	X1-EVC-7.2K(SXH) X1-EVC-7.2K(PXH)	X3-EVC-11K(SXH) X3-EVC-11K(PXH)	X3-EVC-22K(SXH) X3-EVC-22K(PXH)		
AC Nominal Input					
Phases/Lines	L+N+PE	3P+N+PE	3P+N+PE		
Voltage [V]	230	400	400		
Frequency [Hz]	50/60;±5	50/60;±5	50/60;±5		
AC Nominal Output					
Voltage [V]	230	400	400		
Current [A]	32	16	32		
Power [W]	7200	11000	22000		
Interface					
RS485		YES			
RFID Frequency		13.56 M			
LCD Screen		Optional			
CT Clamps	x1	х3	х3		
Housing Material	Plastic/Metal				
Installation Method	Wall-mounted(Optional: pedestal-mounted)				
Wall-mount Bracket	YES				
Charging Outlet	Socket Type(Socket-outlet)/Plug Type (Charging cable with connector)				
Cable Length [m]	6.5(for Plug Type)				
Operating Temperature [°C]	-30~+50				
Working Humidity	5%~	95% without condensati	on		
Working Altitude [m]		<2000			
Degree of Protection		IP65			
Protection Class		Class I			
Application Site		Indoor/Outdoor			
Cooling Method		Natural cooling			
Dimension (W*H*D)[mm]	249*370*155(for Socket Type)/265*370	0*155(for Plug Type)		
Net Weight [kg]	7(for Socket Type)/10.5(for Plug Type)				
Communication Info					
Communication Mode		WiFi			
EIRP Power	17.41 d	Bm(Measured Max. Avera	age)		
Frequency		2412~2484 MHz			
Antenna Gain		4 dBi			
Antenna Type	IPEX				
Wireless Mode		802.11 b/g/n			

Technical Data Installation

4.2 Security Protection

Model	X1-EVC-7.2K(SXH) X1-EVC-7.2K(PXH)	X3-EVC-11K(SXH) X3-EVC-11K(PXH)	X3-EVC-22K(SXH) X3-EVC-22K(PXH)	
Multiple Protection				
Over/Under voltage protection		YES		
Overload protection	YES			
Current leakage monitoring	Integrated current failure monitoring (30 mA AC & 6 mA DC) *			
Grounding protection	YES			
Surge protection	YES			
Over temperature protection	YES			
Safety Standard	IEC61851-1; IEC62196-2			
Built-in PEN fault technology	YES			
Warranty	3 years			

^{*}This document does not replace any regional, state, provincial or national laws, regulations or standards that apply to the installation, electrical safety and use of the product. Always observe the local regulations as well.

5 Installation

5.1 Check for Transport Damage

Make sure the EV-Charger is intact during transportation. If there are some visible damages, such as cracks, please contact your dealer immediately.

5.2 Packing List

Open the package and fetch out the product, check the accessories at first. The packing list is shown as below.





















Object	Quantity	Description	
Α	1	EV-Charger	
В	3/5	Expansion bolt (3 for Socket Type, 5 for Plug Type)	
С	3/5	Self tapping screw (3 for Socket Type, 5 for Plug Type)	
D	3/5	Gasket (3 for Socket Type, 5 for Plug Type)	
E	/	Documents	
F	3/5	European terminal (3 for single-phase; 5 for three-phase)	
G	1	RJ45 terminal adapter	
Н	2	RFID card	
	1	CT (I1 for single-phase; I2 for three-phase)	
J	1	Cable hook (only for Plug Type)	

5.3 Installation Precaution

The EV-Charger is designed for wall-mounted/pedestal-mounted installation (IP65). Make sure the installation site meets the following conditions:

- Not exposed to sunlight directly.
- · Not in areas where highly flammable materials are stored.
- · Not in potential explosive areas.
- · Not near the television antenna or antenna cable.
- · Not higher than altitude of about 2000 m above sea level.
- Not in environment of precipitation or humidity (5%~95%).
- · Make sure that the ventilation is good enough.
- The ambient temperature in the range of -30° C $\sim +50^{\circ}$ C.
- The slope of the wall should be within ±5°.

The wall on which the EV-Charger will be installed should meet the conditions below:

- 1) Solid brick/concrete, or strength equivalent mounting surface;
- 2) The EV-Charger must be supported or strengthened if the wall's strength isn't enough (such as wooden wall, the wall covered by thick layer of decoration).



> Available Space Size





Table: Available Space Size

Position	Min. size
Left	300 mm
Right	400-700 mm
Тор	200 mm
Bottom	1.2-1.5 m
Front	300 mm

5.4 Installation Steps

Preparation


• Below tools are needed before installation.



Wire crimper Cross screwdriver Straight screwdriver


 Prepare a communication cable with RJ45 and an input cable with outer diameter of 12.5-18 mm(three-core for single-phase, five-core for threephase).

STEP 1: Remove the screw from the EV-Charger with the cross screwdriver. Then remove the back bracket away carefully.




STEP 2: Fix the back bracket and the cable hook (only for Plug Type) to the wall.


- Mark the position of the holes.
- Drill holes with φ 8 drill.
- Depth: at least 45 mm.



- Insert the expansion bolts.




- Align the bracket and the cable hook (only for Plug Type) with the holes, and screw the self tapping screws with the cross screwdriver.




STEP 3: Hang the EV-Charger on the wall for trial, then estimate the required length of input cable and communication cable. After that, take the EV-Charger down.


STEP 4: Unscrew the EV-Charger's rear cover with the cross screwdriver and take it down. Then undo the fastening heads and take the waterproof materials away as shown below.



STEP 5: Unscrew the countersunk screw of the base plate of communication board with the cross screwdriver. Then pull the base plate of communication board out.




STEP 6: Insert the prepared communication cable through the waterproof connector in sequence as shown below (If the cable is self-made, also insert the wires into the RJ45 terminals and then use crimping pliers to press them tightly).




PIN	1	2	3	4	5	6	7	8
Definition	L1_CT+	L1_CT-	L2_CT+	A1	B1	L2_CT-	L3_CT+	L3_CT-

^{*} PIN 3, 6, 7, 8 is null for single-phase.


STEP 7: Strip the outer sheath of the input cable as below, ensuring all the wires can reach the terminal blocks with a little excessive length. Use the stripping pliers to strip approx. 12 mm of insulation from the end of all the coloured wires as below. Then crimp the European terminal with the wire crimper.




STEP 8: Insert the input cable through the waterproof connector in sequence as shown below.




STEP 9: Insert the wires into the appropriate holes of the terminal blocks, then block the terminals with the straight screwdriver.




STEP 10: Press the spring upward and push the base plate of communication board in. Then screw the countersunk screw.




STEP 11: Push the rear cover to appropriate position of the cables and screw the self tapping screws with the cross screwdriver. Then tighten the waterproof fastening heads.



STEP 12: Hang the EV-Charger up carefully and steady the EV-Charger with the self tapping screw and the cross screwdriver.




For Plug Type, connect the charging connector with the EV-Charger and hang the connecting cable on the hook.




Installation Installation

5.5 CT Connection

Diagram:



- -Steady the CT on the public grid.
- -Insert the other end of the communication cable and the terminal of CT into each side of the RJ45 terminal adapter.



NOTE!



- Do not place the CT on the N Wire or the PE wire.
 Do not place the CT on the N and L wire simultaneously.
 Do not place the CT on the non-insulated wires.
- When using the three-phase CT, please clip the CT clamps on the corresponding phases (CT-R must be connected to grid L1, CT-S) connected to grid L2, CT-T connected to grid L3).

Installation Operation Method

5.6 Run the EV-Charger

- > Power on the EV-Charger after checking all below steps:
- a) Check that the device is fixed well on the wall.
- b) AC cable is connected to grid correctly.
- Power on the EV-Charger
- Check the status of LED indicators, the Complete light should be on when the EV-Charger starts normally.
- If the Complete light is not on, please check if it is correctly installed and connected to the grid.



WARNING!

Power to the unit must be turned on only after installation work has been completed. All electrical connections must be carried out by qualified personnel in accordance with legislation in force in the country concerned.



NOTE!

Equipment only to be used for the purpose outlined by us.

6 Operation Method

6.1 States

There are six states of the series EV-Charger(home edition), i.e. Idle, Stop, Charge, Complete, Fault and Unavailable.

States	Indicator Light & Description			
Idle	The Complete light is on and the MODE SELECTION button is invalid. The connector is not inserted.			
Stop	The STOP light is on. The EV-Charger is connected with EV but not charging.			
Charge	The corresponding charging mode light is on. The EV-Charger is charging.			
Complete	The Complete light and the STOP light are on at the same time. The EV-Charger has completed charging and the MODE SELECTION button is invalid.			
Fault	The Fault light is on. The EV-Charger is in fault state.			
Unavailable	The four charging mode lights are on at the same time. The EV-Charger is remote upgrading.			

6.2 Start-up Patterns

The series EV-Charger (home edition) has two start-up patterns, namely plug & charge and card-swiping pattern. The plug & charge pattern is the default pattern, and the card-swiping pattern needs to "enable" the "RFID Function" in the APP advanced settings.

1) Plug & charge pattern

For Socket Type, the electronic lock will be locked when the EV-Charger starts charging and unlocked when the charging stops.
For Plug Type, there is no electronic lock.

2) Card-swiping pattern

For Socket Type, the electronic lock will be locked when the EV-Charger starts charging after swiping the card, and unlocked after swiping the card when the charging stops.

For Plug Type, there is no electronic lock.

Note:

The charging can be stopped from the vehicle end or the charger end (by long pressing "MODE SELECTION" button, by APP setting or by swiping card). In card-swiping pattern, the electronic lock will not unlock automatically when the charging stops, and users need to swipe the card again to unlock it.

Operation Method Operation Method

* RFID Function Operation

If the user wants to switch to the card-swiping pattern from the default pattern, the user needs to enable RFID function and do card activation operation in APP advanced settings. Please follow the instructions below:

- 1) Touch "RFID Function" to enable the function as below (Disable by default).
- 2) Activate the RFID card:
- a. **Enable** the Card Activation Mode of Advanced Settings in the APP (Disable by default). Once enabled, the four operating LED indicator lights on the EV-Charger will light up in sequence and cycle.

NOTE!



The default RFID PIN is 111111, the user can modify the RFID PIN before activation, and the password of the RFID card will be updated to the RFID PIN after activation. The password of the RFID card must be consistent with the one set in the APP. The RFID PIN is 6 digits.

- b. Swipe the RFID card at the EV-Charger.
- c. If successfully activated, the EV-Charger will beep.
- d. **Disable** the Card Activation Mode in the APP or wait for 1 minute after activation, the EV-Charger will turn to standby state.



6.3 Charging Modes

Short press the "MODE SELECTION" button, the charging mode will switch among FAST, ECO and GREEN Modes.



Long press the "MODE SELECTION" button, the current charging mode will switch to STOP mode. When the EV-Charger is in STOP mode, short press the "MODE SELECTION" button, the EV-Charger will switch back to the previous charging mode. (Only available in plug & charge pattern.)




Operation Method Operation Method

6.3.1 GREEN Mode

In GREEN Mode, the EV-Charger will maximize the use of surplus power generated from the inverter. According to the minimum start-up charging power, the charging current can be divided into two levels as 3 A and 6 A. The default level is 6 A.


In the 6 A level, the EV-Charger won't use the power generated from grid at all.

In the 3 A level, the EV-Charger would start charging only when photovoltaic power supply is more than 3 A. Meanwhile, if the photovoltaic power supply is less than 6 A, the EV-Charger needs to buy extra electricity from grid for minimum start-up charging power(1.4 kW for single-phase, 4.2 kW for three-phase).



6.3.2 ECO mode

In ECO Mode, the charging power is continuously adjusted according to changes in generation or power consumption elsewhere in the house, thereby minimizing the use of grid power. In this mode, users can set charging current at five different levels, i.e. 6 A, 10 A, 16 A, 20 A and 25 A [Only 6 A & 10 A for X3-EVC-11K(SXH) & X3-EVC-11K(PXH)]. If at any time, the available surplus power falls below the fixed value of power, such as 1.4 kW (4.2 kW for three-phase), the shortfall will be drawn from the grid.



NOTE!




When the series EV-Charger is charging in GREEN or ECO mode: The charging electric vehicle must comply with the IEC61851 standard, otherwise the EV-Charger won't work.

If there is a zero injection requirement for the system, the EV-Charger must communicate with the inverter in order to charge normally.

6.3.3 FAST mode


In FAST Mode, the EV-Charger will charge the EV at the fastest rate regardless of whether the power generated by PV is sufficient and import grid electricity if the power generated by PV is insufficient.



Operation Method Operation Method


6.3.4 Smart Boost

Before using the Smart Boost function, set the desired charging energy (kWh) and end time for the vehicle charging on the APP. The EV-Charger will complete the charging of the EV with desired energy before the preset end time at maximum charging power and will use the photovoltaic power supply as much as possible and minimize the use of grid power. (E.g.: The user needs to charge the EV to 40 kWh before 10:00 AM, then the Charging power is depended on the surplus power generated by the inverter.)




6.3.5 Timer Boost

When using ECO or GREEN charging modes, the EV-Charger can be programmed to 'boost' the current charge in a certain period. In timer boost mode, the charging rate is set to maximum (just like FAST mode), regardless of the amount of available surplus power. This means that the power may be drawn from the mains grid supply during boost times. If the EV is fully charged, the EV-Charger will stop charging.



6.4 Dynamic Load Balance

The series EV-Charger has default dynamic load balancing function. During the charging period, no matter in which work mode, the total power of the house will not exceed the main grid capacity. To ensure the total power of the house doesn't exceed the grid capacity, the charging power will be adjusted in real time following the total load power.



7 App Setting

The screen shots here are for reference only and the actual interfaces may differ. Users can update their APP as needed.

➤ APP account login

• If you don't have the app or monitoring cloud's account yet, you can operate as below:

> Monitoring Cloud Registration

Step 1: Use your smart phone to scan below QR code or search for the keyword "SolaXCloud" in browser to download the Monitoring App.





Step 2: Touch the Setting button at upper left corner of the Monitoring App to choose language.

Step 3: Touch "Create a new account" at the bottom of Monitoring App and fill in the information to create the account.

Step 4: For the first login, click "+" to create site. Fill in site information and type in or scan the Registration No. and follow the instructions to complete the site creation and WiFi connection.




(Example for Registration No.)

• If you already have the account, you can operate as below:

Add Device

Step 1: Login your account and turn to Device page in the app. Step 2: Touch the "+" icon on the upper right corner and fill in the information to add the EV-Charger.



➤ Wi-Fi Connection

Step 1: Login your account and turn to Account page in the app.

Step 2: Click "Wifi Connection".




Step 3: Type in or scan the Registration No. of the EV-Charger. Then touch Next and agree to join the network of the EV-Charger.



Step 4: Type in or choose your home Wi-Fi SSID and password, then touch "Next".

*5GHz Wi-Fi is unavailable for now.




Step 5: Follow the instructions to complete Wi-Fi setting, there will be a note when the setting successes.

*Check more Wi-Fi setting information on www.solaxcloud.com/wifiSetting/

Local Mode

Use your smart phone to connect the SolaX Wi-Fi signal (Wifi_Sxxxxxxxxx). Then touch Local and type in password (initially same as the Registration No.) to access the Local Mode in the Monitoring App.

*Visit the local password setting instruction on www.solaxcloud.com/wifiSetting/



^{*}If manual WiFi configuration is required, the IP address is http://192.168.10.10/.

Settings for the EV-Charger

1. Select "Site" at the bottom and then touch the "EV Charger" icon and select your EV-Charger on the list.



2. Touch the "EV Charger" icon and then touch the setting button to enter the setting page.



3. Select "Mode Settings" and a drop-down list will appear. Set the levels of Green Mode (2 levels) and ECO Mode [5 levels for X1-EVC-7.2K(SXH), X1-EVC-7.2K(PXH), X3-EVC-22K(SXH) & X3-EVC-22K(PXH), 2 Levels for X3-EVC-11K(SXH) & X3-EVC-11K(PXH)] as you want.

<	Setting
Version	1.08
Date Time	2022-09-01 00:00
Mode Settings	٨
Green Mode	Level1 3A
ECO Mode	Level1 6A
Boost Settings	V
Main Breaker Limit	V
Advanced Settings	V

4. Select "Boost Settings" and a drop-down list will appear. Set the Start Time and End Time for Timer Boost, the Charge(kWh) energy and End Time for Smart Boost as you want.

< S	etting
Version	1.08
Date Time	2022-09-01 00:00
Mode Settings	V
Boost Settings	۸
Timer	Boost
Start time	00:00
End time	00:00
Charge (kWh)	Boost ·····
0	Save
End time	00:00
Main Breaker Limit	V
Advanced Settings	V

5. Select "Main Breaker Limit" and set the value. With the dynamic load balance function, when the power consumption approaches the preset max value, the EV-Charger will reduce charge power so that the main breaker current will reduce to the preset value minus 5 A, thus avoid the situation of main breaker trip due to overload.

< Set	ting
Version	1.08
Date Time	2022-09-01 00:00
Mode Settings	V
Boost Settings	V
Main Breaker Limit	٨
Main Breaker Limit (A)	
60	Save
Advanced Settings	٧

6. Select "Advanced Settings" and a drop-down list will appear.

< Sett	ing
Version	1.08
Date Time	2022-09-01 00:00
Mode Settings	V
Boost Settings	٧
Main Breaker Limit	V
Advanced Settings	۸
Overvoltage Limit (V)	
265	Save
Undervoltage Limit (V)	
160	Save
Grid Data Source	СТ
Three-phase in	nbalance ————
Three-phase imbalance	
RFID Fun	ction-
RFID Function	Disable
Card Activation Mode	Disable
Restore factory settings	Save
EV Charger Reset	Save

1) Set and save the value of "Overvoltage Limit" and "Undervoltage Limit".

Overvoltage Limit (V)	
265	Save
Undervoltage Limit (V)	
160	Save

2) Touch "Grid Data Source" to select the source according to the actual application.

Undervoltage Limit (V)	
160	Save
Grid Data Source	СТ

- 3) Settings for "Three-phase imbalance" (Only for single-phase EV-Chargers). In some countries, there are some special regulations that the power differences between the phases must not be bigger than 4.6 kW or 3.7 kW. Therefore, when using single-phase EV-Charger, the charging power must be limited. (This setting item is not available for three-phase EV-Chargers.) If required by local regulations, please enable this function and complete the relative settings:
- a. Select the correct "Charge phase" after consulting with the technical electrician.
- b. Set the value for "Unbalanced power (W)" according to local regulations. The default value is 4600.

Three-phase imbalance	
Times phase imbalance	,
Three-phase imbalance	Enable
Charge phase	L1
Unbalanced power (W)	
4600	Save

NOTE!



To achieve the three-phase imbalance function, the single-phase EV-Charger should be connected with a three-phase meter or communicate with an inverter. If achieved by communicating with an inverter, the inverter must be connected with a three-phase meter or three-phase CT.

4) Touch "RFID Function" to enable or disable the function. Touch "Card Activation Mode" for the activation of the RFID card as described in "RFID Function Operation" of section "Operation Method".

RFID Function		
RFID Function	Disable	
Card Activation Mode	Disable	

5) The default setting can be restored and the EV-Charger can be reset by touching correspondent option.

Restore factory settings	Save
EV Charger Reset	Save

Troubleshooting Troubleshooting

8 Troubleshooting

8.1 Troubleshooting

This section contains information and procedures for solving possible problems with the series EV-Charger, and provides you with troubleshooting tips to identify and solve most problems that could occur with the EV-Charger.

This section will help you narrow down the source of any problems you may encounter. Please read the following troubleshooting steps.

Check warnings or fault messages on System Control Panel or Fault codes on the EV-Charger information panel. If a message is displayed, record it before doing anything further.

Attempt the solution indicated in troubleshooting lists.

No.	Faults	Solution
0	PowerSelect_Fault	Contact installers for help
1	EmStop_Fault	1.Release the Emergency button; 2.Contact installers for help
2	OverVoltL1_Fault	1. Confirm that the Grid Voltage is within the working range; 2. If the "Fault" indicator is off, try charging EV again; 3. If not, set the value of "Overvoltage Limit" to a proper range, the buzzer will beep after the value is saved; 4. repeat step 2; 5. Contact installers for help
3	UnderVoltL1_Fault	1. Confirm that the Grid Voltage is within the working range; 2. If the "Fault" indicator is off, try charging EV again; 3. If not, set the value of "Undervoltage Limit" to a proper range, the buzzer will beep after the value is saved; 4. repeat step 2; 5. Contact installers for help
4	OverVoltL2_Fault	Same as ErrorCode 2
5	UnderVoltL2_Fault	Same as ErrorCode 3
6	OverVoltL3_Fault	Same as ErrorCode 2
7	UnderVoltL3_Fault	Same as ErrorCode 3
8	ElecLock_Fault	Contact installers for help
9	OverLoad_Fault	1. Unplug the connector from the EV; 2. If the "Fault" indicator is off, re-plug in and try charging EV again; 3. If the "Fault" indicator persists, try another EV; 4. Contact installers for help

No.	Faults	Solution
10	OverCurr_Fault	 Unplug the connector from the EV; If the "Fault" indicator is off, re-plug in and try charging EV again; Contact installers for help
11	OverTemp_Fault	1. Unplug the connector from the EV; 2. If the "Fault" indicator is off, re-plug in and try charging EV again; 3. If not, confirm that the conditions for installation are proper and waiting for cooling down, then re-plug in and try charging EV again when the indicator turns off; 4. Contact installers for help
12	PEGround_Fault	1. Unplug the connector from the EV; 2. If the "Fault" indicator is off, check the EV whether it is normal; 3. If not, confirm that all the cables and wires are intact; 4. Contact installers for help
13	PELeakCurr_Fault	1. Unplug the connector from the EV; 2. If the "Fault" indicator is off, check the EV whether it is normal; 3. If not, confirm that all the cables and wires are intact; 4. If the "Fault" indicator is off, re-plug in and try charging EV again; 5. Contact installers for help
14	OverLeakCurr_Fault	Same as ErrorCode 12
15	MeterCom_Fault	Contact installers for help
16	485Com_Fault	1. If the "Fault" indicator is off, try charging EV again; 2. If not, confirm that all the communication wires are intact and confirm the selection of "Grid Data Source"; 3. Restart; 4. Contact installers for help
17	CPVolt_Fault	Same as ErrorCode 12

^{*} When your EV-Charger needs to be upgraded by the service personnel, please make sure to unplug the connector from the EV.

Troubleshooting Troubleshooting

- If your EV-Charger's information panel is not displaying a Fault light, check the following list to make sure that the present state of the installation allows proper operation of the unit.
 - Is the EV-Charger located in a clean, dry, adequately ventilated place?
 - Are the specification and length of the cables suitable?
 - Are the input connections and wiring in good condition?
 - Are the configuration settings correct for your particular installation?
 - Are the display panel and the communication cable properly connected and undamaged?

Contact our Customer Service for further assistance. Please be prepared to describe details of your system installation and provide model and serial number of the unit.

8.2 Routine Maintenance

The EV-Charger do not need any maintenance or correction in most condition. To ensure that the EV-Charger can operate properly for a long term, you are advised to perform routine maintenance on it.

Only trained and authorized professional personnel who are familiar with the requirements of safety was allowed to perform servicing and maintenance work.

► Safety checks

Safety checks should be performed at least every 12 months by manufacturer's qualified person who has adequate training, knowledge, and practical experience to perform these tests. The data should be recorded in an equipment log. If the device is not functioning properly or fails any of the tests, the device has to be repaired. For safety check details, refer to section 2 Safety instruction in this manual.

► Maintain periodically

Only qualified personnel may perform the following works.

During the process of using the EV-Charger, the manage person shall examine and maintain the machine regularly. The concrete operations are as follows.

- 1) Check that if the indicators of the EV-Charger are in normal state, check if the buttons of the EV-Charger are in normal state, check if the display of the EV-Charger is normal. This check should be performed at least every 6 months.
- 2) Check that if the input cable and the connector are damaged or aged. This check should be performed at least every 6 months.
- 3) Check whether the ground terminal and ground cable are securely connected every 12 months.
- 4) Clean the outer shell of the EV-Charger and check its security at least every 6 months.

Decommissioning

9 Decommissioning

9.1 Dismantling the EV-Charger

- Disconnect the EV-Charger from the inverter and the grid.
- · Wait for 5 minutes for de-energizing.
- Remove the EV-Charger from the bracket.
- · Remove the bracket if necessary.

9.2 Packaging

If possible, please pack the EV-Charger with the original packaging. If it is no longer available, you can also use an equivalent carton that meets the following requirements.

- · Suitable for loads more than 10 kg.
- · With handle.
- · Can be fully closed.

9.3 Storage and Transportation

Store the EV-Charger in dry place where ambient temperatures are always between -30 °C \sim +50 °C. Take care of the EV-Charger during the storage and transportation, keep less than 4 cartons in one stack.

9.4 Disposing of the EV-Charger

When the EV-Charger or other related components need to be disposed, have it carried out according to local waste handling regulations. Please be sure to deliver the wasted EV-Charger and packing materials to certain site where can assist relevant department to dispose and recycle.

10 Disclaimer

The EV-Chargers shall be transported, used and operated under restricted conditions. We will not provide any service, technical support or compensation in case of the following conditions, including but not limited to:

- The EV-Charger is damaged by force majeure (such as earthquake, flooding, thunderstorm, lighting, fire hazard, volcanic eruption etc.);
- · The EV-Charger's warranty is expired, but not extended;
- · The EV-Charger's SN, warranty card or invoice cannot be provided;
- · The EV-Charger is damaged by man-made cause;
- The EV-Charger is used or operated against any items in local policy;
- $\cdot \ The \ EV-Charger's installation, configuration, commissioning \ doesn't \ meet the requirements \ mentioned \ in \ this \ manual;$
- · The EV-Charger is installed, refitted or operated in improper ways;
- The EV-Charger is installed, operated under improper environment or electrical condition;
- · The EV-Charger is changed, updated or disassembled on hardware or software without authority from us;
- The communication protocol from other illegal channels is used; and
- The monitoring or control system is used without authority from us. SolaX reserves the right for the final explanation.

Warranty Registration Form



For Customer (Compulsory)		
Name	Country	
	Email	
Address		
State	Zip Code	
Product Serial Number		
Date of Commissioning		
Installation Company Name		
Installer Name	Electrician License No.	
	English Harris	
	For Installer	
Module (If Any)		
Module Brand		
Module Size(W)		
	Number of Panel Per String	
Battery (If Any)		

Please visit our warranty website: https://www.solaxcloud.com/#/warranty to complete the online warranty registration or use your mobile phone to scan the QR code to register.

For more detailed warranty terms, please visit SolaX official website: www.solaxpower.com to check it.



PLEASE REGISTER THE WARRANTY IMMEDIATELY AFTER INSTALLATION! GET YOUR WARRANTY CERTIFICATE FROM SOLAX! KEEP YOUR INVERTER ONLINE & WIN SOLAX POINTS!







