

TEST REPORT

Photovoltaic (PV) systems Characteristics of the utility interface

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

Report reference number:	SXP-18OC1761FCSHP-1
Date of issue	2019-05-27
Total number of pages	65
Testing laboratory name:	Bureau Veritas cofrac LCIE China Company Limited
Address:	Building 4, No. 518, Xinzhuan Road, Caohejing Songjiang High-Tech Park, Shanghai, P.R. China (201612)
Applicant's name:	SolaX Power Network Technology (Zhe jiang) Co., Ltd.
Address:	No. 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing District 311500, Tonglu City, Zhejiang Province, People's Republic of China
Test specification	
Standard:	IEC 61727:2004
Certificate:	Certificate of compliance
Test report form number	IEC 61727
Master TRF:	Bureau Veritas Consumer Products Services Germany GmbH
permitted only with our prior written permission. This set forth in this report are not indicative or represent or identical product unless specifically and express the information that you provided to us. You have 6 by our negligence, provided, however, that such not	r replication of this report to or for any other person or entity, or use of our name or trademark, is a report sets forth our findings solely with respect to the test samples identified herein. The results ative of the quality or characteristics of the lot from which a test sample was taken or any similar y noted. Our report includes all of the tests requested by you and the results thereof based upon 0 days from date of issuance of this report to notify us of any material error or omission caused tice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise te your unqualified acceptance of the completeness of this report, the tests conducted and the
Test item description	Grid-tied photovoltaic inverter
Trademark:	SOLAX
Model / Type:	X1-Hybrid-3.0-N-E, X1-Hybrid-3.0-D-E, X1-Hybrid-3.7-N-E, X1-Hybrid- 3.7-D-E, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-D-E, X1-Hybrid-5.0-N-E, X1-Hybrid-5.0-D-E, X1-Fit-3.7E,X1-Fit-5.0E

Copyright © Bureau Veritas LCIE CHINA



V4 11 1 2 1	VALLE 21		VA 11 1 2 1
•	-		X1-Hybrid- 5.0-N-E, X1-
	-	,	Hybrid-5.0-D-
3.0-D-E	3.7-D-E	4.6-D-E	E
	125-55	0V d.c.	
600V d.c.			
	10/10	A d.c.	
	230V a.c.	50/60Hz	
14,4A a.c.	16A a.c.	21A a.c.	21,7A a.c.
3000VA	3680VA	4600VA	4999VA
	85-400	V d.c.	
20A			
X1-Fit-3.7E	X1-Fit-5.0E		
230\	/ a.c.		
50/6	i0Hz		
16 A a.c.	21,7A a.c.		
3680VA	4999VA		
85-4	00V		
20	A		
	14,4A a.c. 3000VA X1-Fit-3.7E 230V 50/6 16 A a.c. 3680VA 85-4	3.0-N-E, 3.7-N-E, X1-Hybrid- 3.7-D-E 3.0-D-E 125-550 600V 600V 10/10 230V a.c. 14,4A a.c. 16A a.c. 3000VA 3680VA 85-400 20 X1-Fit-3.7E X1-Fit-5.0E 230V a.c. 50/60Hz 16 A a.c. 21,7A a.c.	3.0-N-E, X1-Hybrid- $3.7-D-E$ $4.6-N-E,$ X1-Hybrid- $4.6-D-E$ $3.0-D-E$ $3.7-D-E$ $4.6-D-E$ $125-550V$ d.c. $600V$ d.c. $10/10$ A d.c. $230V$ a.c. $50/60Hz$ $14,4A$ a.c. $16A$ a.c. $21A$ a.c. $3000VA$ $3680VA$ $4600VA$ $3000VA$ $3680VA$ $4600VA$ $X1-Fit-3.7E$ $X1-Fit-5.0E$ $Z0A$ $X1-Fit-5.0E$ $Z0A$ $Z0A$ $X1-Fit-5.0E$ $Z0A$ $Z0A$ $Z0A$ $X1-Fit-3.0A$ $X1-Fit-3A$ <



Bureau Veritas LCIE Cl	hina Company Limited
Building 4, No, 518, Xinz Park, Shanghai, P,R, Ch	zhuan Road, Caohejing, Songjiang High-Tecl iina (201612)
Tony Huang Test engineer	Jorghung
Harvey Wang Project Manager	
SolaX Power Network	Technology (Zhe jiang) Co., Ltd,
No, 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing District 311500, Tonglu City, Zhejiang Province, People's Republic of China	
	Building 4, No, 518, Xinz Park, Shanghai, P,R, Ch Tony Huang Test engineer Harvey Wang Project Manager SolaX Power Network No, 288 Shizhu Road, T Dongxing District 31150

Date	Internal reference	Modification / Change / Status	Revision
2019-05-27	Tony Huang	Initial report was written	0
Supplementary	v information:		



Test items particulars	
Equipment mobility:	Permanent connection
Operating condition	Continuous
Class of equipment	Class I
Protection against ingress of water:	IP65 according to EN 60529
Mass of equipment [kg]:	24kg for X1-Hybrid-3.0-N-E, X1-Hybrid-3.0-D-E, X1-Hybrid-3.7-N-E, X1-Hybrid-3.7-D-E, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-D-E, X1-Hybrid-5.0-N-E, X1-Hybrid-5.0-D-E
	23kg for X1-Fit-3.7E,X1-Fit-5.0E
Test case verdicts	
Test case does not apply to the test object	N/A
Test item does meet the requirement:	P(ass)
Test item does not meet the requirement:	F(ail)
Testing	
Date of receipt of test item	2018-10-30
Date(s) of performance test::	2018-11-14 to 2019-05-16
General remarks:	
The test result presented in this report	relate only to the object(s) tested, part or in full without the written approval of the issuing testing
"(see Annex #)" refers to additional info "(see appended table)" refers to a table	
Throughout this report a comma is use	d as the decimal separator,
	nits of accuracy for the utility voltage and frequency measurement of the at the test table the values for tolerances given in EN 50438, Table 2 are
 Tolerances on trip values tabel 2 EN50 Voltage: +/- 1% of the nominal Frequency: +/- 0,5% of the nor Clearance time: +/- 10% 	voltage
This Test Report consists of the foll	owing documents:
1. Test Results	
2. Annex No, 1 – EMC Test Repo	prt
3. Annex No, 2 – Pictures of the u	unit
4. Annex No, 3 – Test equipment	list



Copy of marking plate:

GRID-CONNECTED PHOTOVOLTAIC INVERTER

DC INPUT	
Max.DC Voltage	600V ====
MPP Voltage Range	125-550V ====
Max.DC Current (Input A/Input B)	10A/10A
Isc PV(Input A/Input B)	14A/14A
Max.DC Power (@cosφ=1)	4000W
AC OUTPUT & AC INPUT	
Nominal AC Voltage, Frequency	230V~,50/60Hz
Nominal AC Apparent Power (@cosø	=1) 3000VA
Max. AC Output/Input Current	14.4A/14.4A
Power Factor at Rated Power	1
Power Factor Range 0.8 Le	eading- 0.8 Lagging
OTHERS	
EPS Nominal Voltage, Frequency	230V~,50/60Hz
EPS Nominal Apparent Power	4000VA
EPS Rated Current	17.4A
Battery Type	Lithium
Battery Voltage Operation Range	85-400V
Max.Charge and discharge Current	20A
Operating Ambient Temperature Ran	ge -2060°C
Ingress Protection	IP65
Inverter Topology	non-isolated
Protective Class	1
Over Voltage Category	III (MAINS),II (DC
Grid Monitoring AS4777/ VDE-A EN50438/ VDE	R-N 4105/ CEI 0-21 0126-1-1/ G59
DRMO DRM1 DRM2 DRM3 DRM4 DRM5	
werter N:	
egister N:	▲ ▲ ▲ &

SolaX Power Network Technology(Zhe Jiang) Co., Ltd. ADD:No.288 Shizhu Road,Tonglu Economic Development Zone Dongsing District.Tonglu City, Zhejang Province, China. TEL: +86 571 5626 0011 E-mail: into@solaxpower.com www.solaxpower.com MADE_IN_CHINA.

GRID-CONNECTED PHOTOVOLTAIC INVERTER Model: X1-Hybrid-3.0-N-E

Model: X1-Hybrid-3.0-N-E	SOLAX
DC INPUT	
Max.DC Voltage	600V ====
MPP Voltage Range	125-550V ====
Max.DC Current (Input A/Input B)	10A/10A
Isc PV(Input A/Input B)	14A/14A
Max.DC Power (@cosφ=1)	4000W
AC OUTPUT & AC INPUT	
Nominal AC Voltage, Frequency	230V~,50/60Hz
Nominal AC Apparent Power (@cosq	=1) 3000VA
Max. AC Output/Input Current	14.4A/14.4A
Power Factor at Rated Power	1
Power Factor Range 0.8 L	eading- 0.8 Lagging
OTHERS	
EPS Nominal Voltage, Frequency	230V~,50/60Hz
EPS Nominal Apparent Power	4000VA
EPS Rated Current	17.4A
Battery Type	Lithium
Battery Voltage Operation Range	85-400V
Max.Charge and discharge Current	20A
Operating Ambient Temperature Ran	nge -2060°C
Ingress Protection	IP65
Inverter Topology	non-isolated
Protective Class	1
Over Voltage Category	III (MAINS), II (DC)
	AR-N 4105/ CEI 0-21 E0126-1-1/ G59
DRMO DRM1 DRM2 DRM3 DRM4 DRM	15 DRM6 DRM7 DRM8
Inverter SN:	





GRID-CONNECTED PHOTOVOLTAIC INVERTER Model: X1-Hybrid-3.7-D-E LA DC INPUT Max.DC Voltage 600V ==== MPP Voltage Range 125-550V ==== Max.DC Current (Input A/Input B) 10A/10A 14A/14A Isc PV(Input A/Input B) Max.DC Power (@coso=1) 5000W AC OUTPUT & AC INPUT Nominal AC Voltage, Frequency 230V~,50/60Hz Nominal AC Apparent Power (@cosq=1) 3680VA Max. AC Output/Input Current 16A/16A Power Factor at Rated Power 1 0.8 Leading- 0.8 Lagging Power Factor Range OTHERS EPS Nominal Voltage, Frequency 230V~,50/60Hz EPS Nominal Apparent Power 4000VA EPS Rated Current 17.4A Battery Type Lithium Battery Voltage Operation Range 85-400V Max.Charge and discharge Current 20A Operating Ambient Temperature Range -20...60°C Ingress Protection IP65 Inverter Topology non-isolated Protective Class Over Voltage Category III (MAINS), II (DC) AS4777/ VDE-AR-N 4105/ CEI 0-21 EN50438/ VDE0126-1-1/ G59 Grid Monitoring DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8 Inverter SN: Register SN: ۮ 🚳 🚳 🛆 🏝 | 🚇 | 🛞 | 🕭 | 🕭 Ġ

SolaX Power Network Technology(Zhe Jiang) Co, Ltd. ADD:No.288 Shizhu Road:Tonglu Economic Development Zone. Donguing District;Tonglu City, Zhejjang Province, China. TEL: +86 571 5626 0011 E-mail: info@solaxpower.com www.solaxpower.com MADE:ID: CHINA.

Copyright © Bureau Veritas LCIE CHINA



GRID-CONNECTED PHOTOVOLTAIC INVERTER Model: X1-Hybrid-3.7-N-E	GRID-CONNECTED PHOTOVOLTAIC INVERTER Model: X1-Hybrid-4.6-D-E	GRID-CONNECTED PHOTOVOLTAIC INVERTER Model: X1-Hybrid-4.6-N-E
DC INPUT	DC INPUT	DC INPUT
Max.DC Voltage 600V	Max.DC Voltage 600V	Max.DC Voltage 600V
MPP Voltage Range 125-550V	MPP Voltage Range 125-550V	MPP Voltage Range 125-550V
Max.DC Current (Input A/Input B) 10A/10A	Max.DC Current (Input A/Input B) 10A/10A	Max.DC Current (Input A/Input B) 10A/10A
Isc PV(Input A/Input B) 14A/14A	Isc PV(Input A/Input B) 14A/14A	Isc PV(Input A/Input B) 14A/14A
Max.DC Power (@cosq=1) 5000W	Max.DC Power (@cosq=1) 6000W	Max.DC Power (@cosφ=1) 6000W
AC OUTPUT & AC INPUT	AC OUTPUT & AC INPUT	AC OUTPUT & AC INPUT
Nominal AC Voltage, Frequency 230V~,50/60Hz	Nominal AC Voltage, Frequency 230V~,50/60Hz	Nominal AC Voltage, Frequency 230V~,50/60Hz
Nominal AC Apparent Power (@cosφ=1) 3680VA	Nominal AC Apparent Power (@cosq=1) 4600VA	Nominal AC Apparent Power (@cosq=1) 4600VA
Max. AC Output/Input Current 16A/16A	Max, AC Output/Input Current 21A/21A	Max. AC Output/Input Current 21A/21A
Power Factor at Rated Power 1	Power Factor at Rated Power 1	Power Factor at Rated Power 1
Power Factor Range 0.8 Leading - 0.8 Lagging	Power Factor Range 0.8 Leading- 0.8 Lagging	Power Factor Range 0.8 Leading - 0.8 Lagging
OTHERS	OTHERS	OTHERS
EPS Nominal Voltage, Frequency 230V~,50/60Hz	EPS Nominal Voltage, Frequency 230V~,50/60Hz	EPS Nominal Voltage, Frequency 230V~,50/60Hz
EPS Nominal Apparent Power 4000VA	EPS Nominal Apparent Power 5000VA	EPS Nominal Apparent Power 5000VA
EPS Rated Current 17.4A	EPS Rated Current 21.7A	EPS Rated Current 21.7A
Battery Type Lithium	Battery Type Lithium	Battery Type Lithium
Battery Voltage Operation Range 85-400V	Battery Voltage Operation Range 85-400V	Battery Voltage Operation Range 85-400V
Max.Charge and discharge Current 20A	Max.Charge and discharge Current 20A	Max.Charge and discharge Current 20A
Operating Ambient Temperature Range -2060°C	Operating Ambient Temperature Range -2060 °C	Operating Ambient Temperature Range -2060°C
Ingress Protection IP65	Ingress Protection IP65	Ingress Protection IP65
Inverter Topology non-isolated	Inverter Topology non-isolated	Inverter Topology non-isolated
Protective Class I	Protective Class I	Protective Class
Over Voltage Category III (MAINS), II (DC)	Over Voltage Category III (MAINS), II (DC)	Over Voltage Category III (MAINS), II (DC)
Grid Monitoring AS4777/ VDE-AR-N 4105/ CEI 0-21 EN50438/ VDE0126-1-1/ G59	Grid Monitoring AS4777/ VDE-AR-N 4105/ CEI 0-21 EN50438/ VDE0126-1-1/ G59	Grid Monitoring AS4777/ VDE-AR-N 4105/ CEI 0-21 EN50438/ VDE0126-1-1/ G59
DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8	DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8	DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8
Inverter SN:	Inverter SN:	Inverter SN:
Register SN:	Register SN:	Register SN:
C € (∰) [№] ▲ ▲ ▲ ▲ ▲ ▲ ▲ ▲ ▲ ▲ ▲ ▲		(€) (10) (10) (10) (10) (10) (10) (10) (10
SolaX Power Network Technology(Zhe Jiang) Co., Ltd. AD:No.288 Shizhu Road,Tonglu Economic Development Zone, Dongxing District.Tonglu City. Zhejiang Province. China. TEL: +86 571 5626 0011 E-mail: info@solaxpower.com	SolaX Power Network Technology(Zhe Jiang) Co, Ltd. ADD:No.288 Shizhu Road,Tonglu Economic Development Zone, Dongxing District,Tonglu City, Zhejlang Province, China. TEL:+86 571 5626 0011 E-mail: Info@solaxpower.com	SolaX Power Network Technology(Zhe Jiang) Co., Ltd. ADD:No.288 Shizhu Road,Tonglu Economic Development Zone, Dongxing District:Tonglu City, Zhejiang Province, China. TEL: +86 571 5626 0011 E-mail: info@solaxpower.com
www.solaxpower.com MADE IN CHINA	www.solaxpower.com MADE IN CHINA	www.solaxpower.com MADE IN CHINA



GRID-CONNECTED PHOTOVOLTAIC INVERTER

SOLAX

3680VA

16A/16A

1

230V~,50/60Hz

0.8 Leading- 0.8 Lagging

GRID-CONNECTED INVERTER

Nominal AC Apparent Power (@cos@=1)

Model: X1-Fit-3.7E

AC OUTPUT & AC INPUT

Nominal AC Voltage, Frequency

Max. AC Output/Input Current

Power Factor at Rated Power

Power Factor Range

GRID-CONNECTED PHOTOVOLTAIC INVERTER Model: X1-Hybrid-5.0-D-E	5	DLAX
DC INPUT		
Max.DC Voltage	600V	
MPP Voltage Range	125-550V	
Max.DC Current (Input A/Input B)	10	A/10A
Isc PV(Input A/Input B)	14	A/14A
Max.DC Power (@cosφ=1)	6	000W

(()) 🐼 🚳 🚳

🏝 🔊 🛞 🖉 🌆

ADD:No.288 Shizhu Road,Tonglu Economic Development Zone, Dongxing District,Tonglu City, Zhejiang Province, China. TEL: +86 571 5626 0011 E-mail: info@solaxpower.com

SolaX Power Network Technology(Zhe Jiang) Co., Ltd.

www.solaxpower.com

Inverte SN:

Register SN:

	N
	· 1
- N	
SOLAX	

MADE IN CHINA

Model: X1-Hybrid-5.0-D-E	Model: X1-Hybrid-5.0-N-E
DC INPUT	DC INPUT
Max.DC Voltage 600V ===	Max.DC Voltage 600V ===
MPP Voltage Range 125-550V	MPP Voltage Range 125-550V
Max.DC Current (Input A/Input B) 10A/10A	Max.DC Current (Input A/Input B) 10A/10A
Isc PV(Input A/Input B) 14A/14A	Isc PV(Input A/Input B) 14A/14A
Max.DC Power (@cosq=1) 6000W	Max.DC Power (@cosq=1) 6000W
AC OUTPUT & AC INPUT	AC OUTPUT & AC INPUT
Nominal AC Voltage, Frequency 230V~,50/60Hz	Nominal AC Voltage, Frequency 230V~,50/60Hz
Nominal AC Apparent Power (@cosφ=1) 4999VA	Nominal AC Apparent Power (@cosφ=1) 4999VA
Nominal AC Apparent Power for VDE 4105 (@ccosp=1) 4600VA	Nominal AC Apparent Power for VDE 4105 (@cosp=1) 4600VA
Max. AC Output/Input Current 21.7A/21.7A	Max. AC Output/Input Current 21.7A/21.7A
Power Factor at Rated Power 1	Power Factor at Rated Power 1
Power Factor Range 0.8 Leading- 0.8 Lagging	Power Factor Range 0.8 Leading- 0.8 Lagging
OTHERS	OTHERS
EPS Nominal Voltage, Frequency 230V~,50/60Hz	EPS Nominal Voltage, Frequency 230V~,50/60Hz
EPS Nominal Apparent Power 5000VA	EPS Nominal Apparent Power 5000VA
EPS Rated Current 21.7A	EPS Rated Current 21.7A
Battery Type Lithium	Battery Type Lithium
Battery Voltage Operation Range 85-400V	Battery Voltage Operation Range 85-400V
Max.Charge and discharge Current 20A	MaxCharge and discharge Current 20A
Operating Ambient Temperature Range -2060°C	Operating Ambient Temperature Range -2060 °C
Ingress Protection IP65	Ingress Protection IP65
Inverter Topology non-isolated	Inverter Topology non-isolated
Protective Class I	Protective Class I
Over Voltage Category III (MAINS), II (DC)	Over Voltage Category III (MAINS), II (DC)
Grid Monitoring AS4777/ VDE-AR-N 4105/ CEI 0-21 EN50438/ VDE0126-1-1/ G59	Grid Monitoring AS4777/ VDE-AR-N 4105/ CEI 0-21 EN50438/ VDE0126-1-1/ G59
DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8	DRMO DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8



www.solaxpower.com

EPS OUTPUT EPS Nominal Voltage, Frequency 230V~,50/60Hz EPS Nominal Apparent Power 4000VA EPS Rated Current 17.4A BATTERY Battery Type Lithium 85-400V Battery Voltage Operation Range Max.Charge and discharge Current 20A OTHERS Operating Ambient Temperature Range -20...60°C Ingress Protection IP65 Inverter Topology non-isolated Protective Class Over Voltage Category III (MAINS), II (DC) A\$4777/ VDE-AR-N 4105/ CEI 0-21 Grid Monitoring EN50438/ VDE0126-1-1/ G59 DRM0 DRM1 DRM2 DRM3 DRM4 DRM5 DRM6 DRM7 DRM8 Inverter SN: Register SN: 🔬 | 🎯 🞯 🔇 X 🙉 🔊 C٠ SolaX Power Network Technology(Zhe Jiang) Co., Ltd. ADD:No.288 Shizhu Road,Tonglu Economic Development Zo Dongxing District,Tonglu City, Zhejiang Province, China. ent Zone. TEL: +86 571 5626 0011 E-mail: info@solaxpower.com

www.solaxpower.com

MADE IN CHINA

Copyright @ Bureau Veritas LCIE CHINA

The Accreditation only attests the technical capability of the testing laboratory for the test covered by the accreditation" (in the case of case of test report issued under accreditation mark)

MADE IN CHINA




	SOLAX
C OUTPUT & AC INPUT	
Nominal AC Voltage, Frequency	230V~,50/60Hz
Nominal AC Apparent Power (@	cosφ=1) 4999VA
Nominal AC Apparent Power for VDE	4105 (@cosφ=1) 4600VA
Max. AC Output/Input Current	21.7A/21.7A
Power Factor at Rated Power	1
Power Factor Range (0.8 Leading- 0.8 Lagging
PS OUTPUT	
PS Nominal Voltage, Frequency	/ 230V~,50/60Hz
EPS Nominal Apparent Power	5000VA
EPS Rated Current	21.7A
BATTERY	
Battery Type	Lithium
Battery Voltage Operation Range	
Max.Charge and discharge Curre	ent 20A
OTHERS	Deces and
Operating Ambient Temperature	
ngress Protection	IP65 non-isolated
nverter Topology	non-isolated
Protective Class	
Over Voltage Category	III (MAINS),II (DC)
	DE-AR-N 4105/ CEI 0-21 VDE0126-1-1/ G59
DRM0 DRM1 DRM2 DRM3 DRM4	DRM5 DRM6 DRM7 DRM8
verter I:	
egister N: CCC () ∠ X ∩	
NE CCC I I I I I I I I I I I I I I I I I I	(Zhe Jiang) Co., Ltd. conomic Development Zone,



General product information:

The Solar Inverter converts DC voltage into AC voltage.

The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error. The PV inverters can also be used with an energy storage system, utilize the advanced power conversion technology IGBT to convert DC to AC.



The internal control is redundant built, It consists of master controller(U2-A) and slave controller(U2-B), the master controller(U2-A) can control relays, measures voltage, frequency, AC current with injected DC, insulation resistance and residual current. The slave controller (U2-B) can control the relays, measures the voltage and frequency. Both controllers communicate with each other.

The voltage and frequency measurement is achieved with resistors in serial which are connected directly to line and neutral. Both controllers get these signals and calculate the data.

The protection device makes up of two in series in each line and netural between inverter and grid .Inverter and back-up load.Back-up load and grid.Communicative coupled AC relays so that the equipment could be effectively separated from utility even any one of relays short circuited or works unnormally.

The controlling section is also redundant built. one master DSP. and one slave DSP. The master DSP carries out the main calculation and driving instructions. Slave DSP is responsible for the redundant relay independently. In case any one of two chips breaks down or runs a wrong program. which result to the loss of protection funciton. the another chip could indicate the fault and disconnect the equipment immediately.



Hardware Version:

Model	X1-Hybrid- 3.0-N-E	X1-Hybrid- 3.0-D-E	X1-Hybrid- 3.7-N-E 3.7-D-E		X1-Hybrid- 4.6-N-E	
power board		710.00162.00				
control board	710.70	548.00	710.60	710.50458.0 0		
LCD board		710.00177.00				
USB Board	710.00197.00					
EMI Board	710.10218.00					

Model	X1-Hybrid- 4.6-D-E	X1-Hybrid- 5.0-N-E	X1-Hybrid- 5.0-D-E	X1-Fit-3.7E	X1-Fit-5.0E
power board		710.00162.00	710.10162.00		
control board	710.50548.0 0	710.40	548.00	710.J0458.0 0	710.E0458.0 0
LCD board			710.00177.00		
USB Board	710.00197.00				
EMI Board	710.10218.00			710.10270.0 0	710.10270.0 0

Software Version:

Model	X1-Hybrid-3.0-N-E, X1-Hybrid-3.0-D-E, X1-Hybrid-3.7-N-E, X1-Hybrid-3.7-D-E, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-D-E, X1-Hybrid-5.0-N-E, X1-Hybrid-5.0-D-E, X1-Fit-3.7E,X1-Fit-5.0E
ARM	V2.03
DSP master	V2.07
DSP slave	V2.01



in the difference		mouels w	num a 50				
Model	R411	R412	R413	R328	R62	DC switch	DC conne ctor
X1-Hybrid- 3.0-N-E	Y	N	N	N	Ν	Ν	Y
X1-Hybrid- 3.0-D-E	Y	N	N	N	Ν	Y	Y
X1-Hybrid- 3.7-N-E	N	Y	N	N	Ν	Ν	Y
X1-Hybrid- 3.7-D-E	N	Y	N	Ν	Ν	Y	Y
X1-Hybrid- 4.6-N-E	Y	Y	N	N	Ν	Ν	Y
X1-Hybrid- 4.6-D-E	Y	Y	N	N	Ν	Y	Y
X1-Hybrid- 5.0-N-E	N	N	N	N	Ν	Ν	Y
X1-Hybrid- 5.0-D-E	N	N	N	N	Ν	Y	Y
X1-Fit-3.7E	Ν	Y	N	Y	Y	N	Ν
X1-Fit-5.0E	N	N	Y	Y	Y	Ν	N

Description of the differences of the models within a series:

Note:

Y: have

N: haven't

Note:

The product was tested on:

The tests had been performed on model X1-Hybrid-5.0-D-E are valid for model X1-Hybrid-3.0-N-E, X1-Hybrid-3.0-D-E, X1-Hybrid-3.7-N-E, X1-Hybrid-3.7-D-E, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-D-E, X1-Hybrid-5.0-N-E, X1-Fit-3.7E,X1-Fit-5.0E since it is identical in hardware and just power derated by except for R411, R412, R413, R328, R62, DC Switch, DC Connector.



Default interface protection settings according IEC 61727:2004 TNB Technical Guidebook on Grid-interconnection of Photovoltaic Power Generations System to LV and MV Networks:2013

Parameter	Max. clearance time*	Trip setting			
Over voltage (level 2)	0.05s	230V +20% (276V)			
Over voltage (level 1)	2.0s	230V +10% (253V)			
Under voltage (level 1)	2.0s	230V -15% (195.5V)			
Under voltage (level 2)	0.1s	230V -50% (115V)			
Over frequency	0.2s	50Hz +2% (51.0Hz)			
Under frequency	0.2s	50Hz -2% (49.0Hz)			
Reconnection time	20s to 300s				
Permanent DC-injection	1% of rated inve	rter output current			
Loss of main IEC 62116:2008	Inverter shall detect and disconnect within 2s				

* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the "reconnect" feature.



IEC61727:2004						
Clause	Requirement – Test	Result – Remark	Verdict			
	SECTION 4: Utility compatibili	ty				
4	General The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage. flicker. frequency. harmonics and power factor. Deviation from these standards represents out-of-bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system. All power quality parameters (voltage. flicker. frequency. harmonics. and power factor) must be measured at the utility interface/ point of common coupling unless otherwise specified.	Noticed	P			
4.1	Voltage. current and frequency The PV system AC voltage. current and frequency shall be compatible with the utility system.	Derived from tests	Р			
4.2	Normal voltage operating range Utility-interconnected PV systems do not normally regulate voltage; they inject current into the utility. Therefore. the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions. not as a voltage regulation function.	Derived from tests	P			
4.3	Flicker The operation of the PV system should not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.	See table 4.3 and Annex No. 1. The test report is stored in Bureau Veritas LCIE China Company Limited.	P			
4.4	DC injection The PV system shall not inject DC current greater than 1 % of the rated inverter output current. into the utility AC interface under any operating condition.	See table 4.4	Р			
4.5	Normal frequency operating range The PV system shall operate in synchronism with the utility system. and within the frequency trip limits defined in 5.2.2.	See table 4.5 and 5.2.2	Р			



IEC61727:2004									
Clause	Requirement – Test	Result – Remark	Verdict						
	SECTION 4: Utility compatibility								
4.6	 Harmonics and waveform distortion Low levels of current and voltage harmonics are desirable; the higher harmonic levels increase the potential for adverse effects on connected equipment. Acceptable levels of harmonic voltage and current depend upon distribution system characteristics. type of service. connected loads/apparatus. and established utility practice. The PV system output should have low current-distortion levels to ensure that no adverse effects are caused to other equipment connected to the utility system. Total harmonic current distortion shall be less than 5 % at rated inverter output. Each individual harmonic shall be limited to the percentages listed in Table 1. Even harmonics in these ranges shall be less than 25 % of the lower odd harmonic limits listed. (see Clause 4.6 Table 1 – Current distortion limits) 	See tables 4.6 and Annex No.1	P						
4.7	Power factor The PV system shall have a lagging power factor greater than 0.9 when the output is greater than 50 % of the rated inverter output power.	See table 4.7	Р						



IEC61727:2004							
Clause	Requirement – Test	Result – Remark	Verdict				
	SECTION 5: Personnel safety and equipme	ent protection					
5	General This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.	Noticed	P				
5.1	Loss of utility voltage To prevent islanding. a utility connected PV system shall cease to energize the utility system from a de-energized distribution line irrespective of connected loads or other generators within specified time limits. A utility distribution line can become de-energized for several reasons. For example. a substation breaker opening due to fault conditions or the distribution line switched out during maintenance. If inverters (single or multiple) have DC SELV input and have accumulated power below 1 kW then no mechanical disconnect (relay) is required.	The loss of utility voltage test report for IEC61727 according to IEC62116 is stored in archive at Bureau Veritas LCIE China Company Limited.	Ρ				
5.2	Over/under voltage and frequency Abnormal conditions can arise on the utility system that requires a response from the connected photovoltaic system. This response is to ensure the safety of utility maintenance personnel and the general public. as well as to avoid damage to connected equipment. including the photovoltaic system. The abnormal utility conditions of concern are voltage and frequency excursions above or below the values stated in this Clause. and the complete disconnection of the utility. presenting the potential for a distributed resource island.	See table 5.2.1 and 5.2.2	Ρ				
5.2.1	Over/under voltageWhen the interface voltage deviates outside the conditions specified in Table 2. the photovoltaic system shall cease to energize the utility distribution system. This applies to any phase of a multiphase system. All discussions regarding system voltage refer to the local nominal voltage. The system shall sense abnormal voltage and respond. The following conditions should be met. with voltages in RMS and measured at the point of utility connection. (see clause 5.2.1 Table 2 – Response to abnormal voltages)The purpose of the allowed time delay is to ride through short-term disturbances to avoid excessive nuisance tripping. The unit does not have to cease to energize if the voltage returns to the normal utility continuous operation condition within the specified trip time.	See table 5.2.1	Ρ				



	IEC61727:2004		
Clause	Requirement – Test	Result – Remark	Verdict
	SECTION 5: Personnel safety and equipme	ent protection	
5.2.2	 Over/under frequency When the utility frequency deviates outside the specified conditions the photovoltaic system shall cease to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time. When the utility frequency is outside the range of ±1 Hz. the system shall cease to energize the utility line within 0.2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions. 	See table 5.2.2	P
5.3	Islanding protection The PV system must cease to energize the utility line within 2 s of loss of utility.	The loss of utility voltage test report for IEC61727 according to IEC62116 is stored in archive at Bureau Veritas LCIE China Company Limited.	P
5.4	Response to utility recovery Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing. the photovoltaic system shall not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.	See table 5.2 (1) and 5.2 (2)	Ρ
5.5	Earthing The utility interface equipment shall be earthed/grounded in accordance with IEC 60364-7-712.	Stated in the manual.	Р
5.6	Short circuit protection The photovoltaic system shall have short-circuit protection in accordance with IEC 60364-7-712.	Stated in the manual.	Р
5.7	Isolation and switching A method of isolation and switching shall be provided in accordance with IEC 60364-7-712.	Stated in the manual.	Р



Test overview:

IEC 61727:2004					
Clause		Result			
1	Response to protection operation - fault condition tests (according VDE0126- 1-1:2006)	Р			
4	Type test:				
4.3	Voltage Fluctuations and Flicker	Р			
4.4	Monitoring of DC-Injection	Р			
4.5	Normal frequency operating range (see 5.2.2 below)	Р			
4.6	Harmonics and waveform distortion	Р			
4.7	Power factor	Р			
5.2.1	Voltage monitoring	Р			
5.2.2	Frequency monitoring	Р			



Test Results

1. Response to protection operation - fault condition tests										Р	
	tem [°C]		24.0°C								
	of p sup	del/type ower ply :		AC: type 61512							
	er c sup	nufactur of power ply :	AC: Ch DC: Ch								
	pow	rkings of		AC: 18kW three phase DC: 15kW. 15A. 1000V							
component No.		fault	test co AC	ndition DC	test time	fuse No.	fault c AC	ondition DC	- re	sult	
Output L-N		Short circuit	230V 21,7A	500V 10A	1min		230V <0,1A	500V <0,1A	Unit shut dow message:" Gi Fault ", no da hazard, no fir	id Loss mage, no	
Input PV+ to PV-)	Short circuit before startup	230V <0,1A	500V 0,1A	1min		230V <0,1A	500V <0,1A	Unit can't start up, kept in waiting, no damage, no hazard, no fire.		
Input PV+ to PV-)	Revers e	230V <0,1A	500V 0,1A	1min		230V <0,1A	500V <0,1A	Unit can't start up, kept in waiting, no damage, no hazard, no fire.		
Battery+ to battery-		Short circuit	230V 21,7A	500V 10A	1min		230V 21,7A	500V 10A	Unit operates normal, no damage, no hazard, no fire.		
Battery+ to battery		Revers e	230V 21,7A	500V 10A	1min		230V <0,1A	500V <0,1A	Unit shut dow message:"BA Fault", no dar hazard, no fir	T ConDir nage, no	
RY3		Short circuit before startup	230V <0,1A	500V 0,1A	1min		230V <0,1A	500V <0,1A	Unit can't start up, message:"Grid Relay Fault no damage, no hazard, no fire.		



LCIE							
RY4	Short circuit before startup	230V <0,1A	500V 0,1A	1min	 230V <0,1A	500V <0,1A	Unit can't start up, message:"Grid Relay Fault", no damage, no hazard, no fire.
RY5	Short circuit before startup	230V <0,1A	500V 0,1A	1min	 230V <0,1A	500V <0,1A	Unit can't start up, message:"Grid Relay Fault", no damage, no hazard, no fire.
RY6	Short circuit before startup	230V <0,1A	500∨ 0,1A	1min	 230V <0,1A	500V <0,1A	Unit can't start up, message:"Grid Relay Fault", no damage, no hazard, no fire.
Grid voltage resistance monitoring to Master DSP R256	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"Grid Volt Fault", no damage, no hazard, no fire.
Grid voltage resistance monitoring to Master DSP R260	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"DCI OCP Fault", no damage, no hazard, no fire.
Grid voltage resistance monitoring to Slaver DSP R252	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"Sample Fault", no damage, no hazard, no fire.
Grid voltage resistance monitoring to Slaver DSP R261	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"Sample Fault", no damage, no hazard, no fire.
Grid voltage resistance monitoring to Slaver DSP R244	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"Sample Fault", no damage, no hazard, no fire.
Grid voltage resistance monitoring to Slaver DSP R262	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"Sample Fault", no damage, no hazard, no fire.
Grid voltage resistance monitoring to Slaver DSP R248	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"Grid Volt Fault", no damage, no hazard, no fire.
Grid voltage resistance monitoring to Slaver DSP R281	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"DCI OCP Fault", no damage, no hazard, no fire.
Q2 D-S	Short circuit	230V 21,7A	500V 10A	1min	 230V 21,7A	500V 10A	Unit operates normal, no damage, no hazard, no fire.



Page 20 of 65

Report No.: SXP-18OC1761FCSHP-1

Q2 G-S	Short circuit	230V 21,7A	500V 10A	1min	 230V 21,7A	500V 10A	Unit operates normal, no damage, no hazard, no fire.
Q3 D-S	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, Q3 brokenno damage, no hazard, no fire.
Q3 G-S	Short circuit	230V 21,7A	500V 10A	1min	 230V 21,7A	500V 10A	Unit operates normal, no damage, no hazard, no fire.
Q6 D-S	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, Q3 brokenno damage, no hazard, no fire.
Q6 G-S	Short circuit	230V 21,7A	500V 10A	1min	 230V 21,7A	500V 10A	Unit operates normal, no damage, no hazard, no fire.
DC BUS Capacitor C5	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, C5 broken,no damage, no hazard, no fire.
R171	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500V <0,1A	Unit shut down, error message:"ISO Fault", no damage, no hazard, no fire.
R172	Short circuit	230V 21,7A	500V 10A	1min	 230V <0,1A	500∨ <0,1A	Unit shut down, error message:"ISO Fault", no damage, no hazard, no fire.
Noto:					 		

Note:

The errors in the control circuit simulate that the safety is even ensured during single fault. Details for the error code please refer user manual.



Test conditions:	Maximum permissible voltage fluctuation (expressed as a percentage of nominal voltage at 100 % power) and flicker as per EN 61000-3-11							
	Starting	Stopping	Run	ning				
Limit	3.3%	3.3%	P _{st} =1.0	Pit=0.65				
Test value	*	*	*	*				
Limit	dc%	= 3.3	P _{st} =1.0	Pit=0.65				
X1-Hybrid-5.0-D-E	0.	39	0,46	0,35				
Note: *The stationary deviance of de Mains Impedance according B Bei Einphasigen Invertern Zm	EN61000-3-11: R _{max}	=0.4 Ω; jX _{max} =0.2	5 Ω @50Hz (Z _{max} =					


 $Z_{max} = Z_{ref} * 3.3\% / d_c(P_n)$

The tests should be based on the limits of the EN 61000-3-11 for more than 16A.



4.4 Monitoring of Permanent DC-Injection IEC 61727:2004									
Model: X1-Hybrid-5.0-D-E									
Test conditions:	U _N = 230 V _{AC} Uinput =360 V _{DC} Rated Power:5000 W								
DC Injection (A)	Limits	Trip Time (ms)		s)					
+1.0A	I _{DC} :>1A than disconnection within 0.2 sec	150	152	149					
-1.0A	I _{DC} :>1A than disconnection within 0.2 sec 140 138		149						
Note: A dc-current of 1A is inje	ected. disconnection time of max. 0.2s		•	-					






Copyright © Bureau Veritas LCIE CHINA



4.4 Monitoring of Perman IEC 61727:2004	ent DC-Injection		Р			
Model: X1-Hybrid-5.0-D-E						
IEC61727 Limit:	1% of Inom (108mA)					
Output power:	25%	50%	100%			
mean test value:	32,3 44,0 101,0					
Model: X1-Hybrid-3.0-D-E						
IEC61727 Limit:		1% of Inom (72mA)				
Output power:	25%	50%	100%			
mean test value:	36,0	22,0	38			





Copyright © Bureau Veritas LCIE CHINA



Model: X1-H	ybrid-5.0-D-E			
	Watts(W)		4988.	8
	VA(VA)		4988, 4991,	
	Vrms(V)		230,0	
	Arms(A)		230,0	
	PF		0,999	
	Frequency(Hz)		50	0
			1,35	
Harmonics	Current Magnitude [A]	% of Fundamenta		Harmonic Current Limits [%]
1st	21,67		single phase	
2nd	0,163	0,754	single phase	1%
3rd	0,210	0,968	single phase	4%
4th	0,008	0,039	single phase	1%
5th	0,052	0,238	single phase	4%
6th	0,006	0,028	single phase	1%
7th	0,029	0,136	single phase	4%
8th	0,005	0,021	single phase	1%
9th	0,021	0,098	single phase	4%
10th	0,004	0,020	single phase	0,5%
11th	0,027	0,127	single phase	2%
12th	0,006	0,025	single phase	0,5%
13th	0,033	0,150	single phase	2%
14th	0,007	0,033	single phase	0,5%
15th	0,043	0,197	single phase	2%
16th	0,009	0,041	single phase	0,5%
17th	0,042	0,195	single phase	1,5%
18th	0,009	0,044	single phase	0,5%
19th	0,039	0,179	single phase	1,5%
20th	0,009	0,043	single phase	0,5%
20th	0,038	0,177	single phase	1,5%
22th	0,010	0,046	single phase	0,5%
23th	0,037	0,172	single phase	0,6%
23th	0,009	0,042	single phase	0,5%
25th	0,009	0,139	single phase	0,5%
26th	0,008	0,038	single phase	0,5%
20th	0,000	0,124	single phase	0,5%
28th	0,008	0,035	single phase	0,5%
29th	0,000	0,107	single phase	0,6%
30th	0,023	0,032	single phase	0,5%
31th	0,007	0,081	single phase	0,5%
32th	0,007	0,030	single phase	0,5%
33th	0,019	0,087	single phase	0,5%
34th	0,019	0,032	single phase	N/A
35th	0,007	0,068	single phase	N/A N/A
36th	0,015	0,008	single phase	N/A N/A
30th	0,008	0,028	single phase	N/A N/A
37th 38th	0,001	0,033	single phase	N/A N/A
	0,006	0,029		N/A N/A
39th 40th	0,012	0,056	single phase single phase	N/A N/A



4,7 Power factor					Р				
Model		X1-Hybrid-5.0-D-E							
Output power [kW]	~10%	~20%	~50%	~75%	~100%				
Test AC voltage [V]	0,50	1,0	2,50	3,75	5,00				
230V	0,9428i	0,9915i	0,9985i	0,9994i	0,9995i				
Model		>	1 K1-Hybrid-4.6-D	-E					
Output power [kW]	~10%	~20%	~50%	~75%	~100%				
Test AC voltage [V]	0,46	0,92	2,30	3,45	4,60				
230V	0,9270i	0,9916i	0,9984i	0,9993i	0,9996i				
Model) 	1-Hybrid-3.7-D	-E					
Output power [kW]	~10%	~20%	~50%	~75%	~100%				
Test AC voltage [V]	0,37	0,74	1,84	2,76	3,70				
230V	0,8908i	0,9837i	0,9970i	0,9986i	0,9994i				
Model		>	(1-Hybrid-3.0-D	-E	<u> </u>				
Output power [kW]	~10%	~20%	~50%	~75%	~100%				
Test AC voltage [V]	0,30	0,60	1,50	2,25	3,0				
230V	0,8389i	0,9756i	0,9956i	0,9981i	0,9989i				
Nata									

Note:

The PV system shall have a lagging power factor greater than 0,95 when the output is greater than 50% of the rated inverter output power,

The letter "i" is short for "inductive" and indicates inductive power factor, In case of capacitive power factor the letter "c" is used instead,



5,2,1 Voltage monitoring

Ρ

IEC 61727: First Level

Model: X1-Hybrid-5.0-D-E

	Under Voltage					Over Vo	tage	
Parameter	Voltage	Time [s]			Voltage	Time [s]		
Limit	195,5V				253V			
Trip value	194,5V	<= 2,0s			254,0 V	<= 2,0s		
Trip time(s)	230V to 190,0 V	1,680	1,656	1,656	230V to 258V	1,048	1,064	1,072
Reconnection time (s)	20s <t<300s< td=""><td></td><td>77,68</td><td></td><td>20s<t<300s< td=""><td></td><td>253,2</td><td></td></t<300s<></td></t<300s<>		77,68		20s <t<300s< td=""><td></td><td>253,2</td><td></td></t<300s<>		253,2	

IEC 61727: Second Level

	Under Voltage					Over Vo	tage	
Parameter	Voltage	Time [ms]			Voltage		Time [ms]	
Limit	115V	100			276V*	50		
Trip value	114,0V	<= 100ms		277,4	<= 50ms			
Trip time(ms)	230V to 110V	84,0	89,6	77,6	230V to 281 V	15,60	9,20	28,00
Reconnection time (s)	20s <t<300s< td=""><td colspan="3">137,8</td><td>20s<t<300s< td=""><td></td><td>137,1</td><td></td></t<300s<></td></t<300s<>	137,8			20s <t<300s< td=""><td></td><td>137,1</td><td></td></t<300s<>		137,1	

Note:

The IEC61727 does not provide any limits of accuracy for the utility voltage and frequency measurement of the PV-system, Therefore the values for tolerances given in EN 50438, Table 2 are used,

Tolerances on trip values tabel 2 EN50438:


- Voltage: +/- 1% of the nominal voltage
- Frequency: +/- 0,5% of the nominal frequency
- Clearance time: +/- 10%

*The voltage is the biggest vaule that the manufacturer declared,









Copyright © Bureau Veritas LCIE CHINA



5,2,2 Frequency monitoring									
d-5.0-D-E									
	Under free	quency		Over frequency					
Frequency		Time [ms]	Frequency	Time [ms]				
	85%U _N	U _N	110%U _N		85%U _N	UN	110%U _N		
49,00Hz		<= 200ms	S	51,00Hz		<= 200ms	S		
	48,99	48,99	48,99		51,01	51,01	51,01		
49,5Hz to 4 8,5Hz	150,4	157,6	166,0	50,5Hz to 5 1,5Hz	120,0	119,6	115,6		
20s <t<300s< td=""><td colspan="3">137,6</td><td>20s<t<300s< td=""><td></td><td>138,4</td><td></td></t<300s<></td></t<300s<>	137,6			20s <t<300s< td=""><td></td><td>138,4</td><td></td></t<300s<>		138,4			
	d-5.0-D-E Frequency 49,00Hz 49,5Hz to 4 8,5Hz	d-5.0-D-E Under free Frequency 85%U _N 49,00Hz 48,99 49,5Hz to 4 8,5Hz 150,4	d-5.0-D-E Under frequency Frequency Time [ms] 85%U _N U _N 49,00Hz <= 200ms 49,5Hz to 4 8,5Hz 150,4 157,6	d-5.0-D-E Frequency Time [ms] 49,00Hz <= 200ms 49,5Hz to 4 8,5Hz 150,4 157,6 166,0	d-5.0-D-E Frequency Frequency 85%UN UN 110%UN 49,00Hz <= 200ms	d-5.0-D-E Under frequency Over frequency Frequency Time [ms] Frequency S5%Un 49,00Hz $<= 200ms$ 51,00Hz 85%Un 49,5Hz to 4 8,5Hz 150,4 157,6 166,0 50,5Hz to 5 1,5Hz 120,0	d-5.0-D-E Over frequency Frequency Frequency Frequency Frequency Sign (ms) A 85%U _N U _N 110%U _N Sign (ms) A 85%U _N U _N A 9,00Hz <= 200ms A 48,99 48,99 A 8,99 48,99 48,99 Sin,00Hz <= 200ms 49,5Hz to 4 8,5Hz 150,4 157,6 166,0 50,5Hz to 5 1,5Hz 120,0 119,6		


Note:

The IEC61727 does not provide any limits of accuracy for the utility voltage and frequency measurement of the PV-system, Therefore the values for tolerances given in EN 50438, Table 2 are used,

Tolerances on trip values tabel 2 EN50438:

- Voltage: +/- 1% of the nominal voltage
- Frequency: +/- 0,5% of the nominal frequency -
- Clearance time: +/- 10% -





Copyright © Bureau Veritas LCIE CHINA



Annex 1

EMC Test Report

(The whole EMC test report was stored in internal of BV LCIE CHINA)





EMC TEST REPORT

For

SOLAX POWER CO., LTD.

X1-Hybrid-single phase

Model No.: X1-Hybrid-3.0-N-E, X1-Hybrid-3.0-D-E, X1-Hybrid-3.0-N-I, X1-Hybrid-3.0-D-I, X1-Hybrid-3.0-N-C, X1-Hybrid-3.0-D-C, X1-Hybrid-3.7-N-E, X1-Hybrid-3.7-D-E, X1-Hybrid-3.7-N-I, X1-Hybrid-3.7-D-I, X1-Hybrid-3.7-N-C, X1-Hybrid-3.7-D-C, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-D-E, X1-Hybrid-4.6-N-I, X1-Hybrid-4.6-D-I, X1-Hybrid-4.6-N-C, X1-Hybrid-4.6-D-C, X1-Hybrid-5.0-N-E, X1-Hybrid-5.0-D-E, X1-Hybrid-5.0-N-I, X1-Hybrid-5.0-D-I, X1-Hybrid-5.0-N-C, X1-Hybrid-5.0-D-C

Prepared for Address	-	SOLAX POWER CO., LTD. No. 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing Disctrict, Tonglu City, Zhejiang Province, People's Republic of China
Prepared by Address	:	EMTEK (NINGBO) CO., LTD. 1/F ., Building 4, No. 1177, Lingyun Road, Ningbo National Hi-Tech Zone, Ningbo, Zhejiang, China
		Tel: +86-574-27907998 Fax: +86-574-27721538

Report Number	1	EN160824004E
Date of Test	1	August 24, 2016 to September 14, 2016
Date of Report	:	September 19, 2016

TRF NO. EN61000-6-3/-6-1/-6-2/A

Page 1 of 62

Report No.: EN160824004E Ver.1.0

Copyright © Bureau Veritas LCIE CHINA





TABLE OF CONTENT

	TEST REPORT DESCRITION		PAGE	
1.	SUMMARY OF TEST RESULT			;
2.	GENERAL INFORMATION			
2.1.	Description of Device (EUT)			1
2.2	Description of Test Facility			ł
2.3			8	
2.4			8	
3.				
3.1.			9	
3.2			9	
3.3			9	
3.4	For Electrostatic Discharge Immun	ity Test	10	í
3.5	For RE Strength Susceptibility Test	t í	10	١
3.6	For Electrical East Translent / Burs	st Immunity Test		i
3.7	For Surge Immunity Test		10	i
3.8.	For Injected Current Susceptibility	Test		Ĺ
3.9	For Magnetic Field Immunity Test.			Ĺ
4.				
4.1.	Block Diagram of Test Setup			2
4.2.				
4.3.				
4.4.	EUT Configuration on Measureme	nt		4
4.5.	Operating Condition of EUT			ł
4.6.				
4.7.				
5.	RADIATED EMISSION MEASUREMEN	NT		ł
5.1.	Block Diagram of Test Setup			5
5.2				
5.3.	Radiated Emission Limits			ŝ
5.4.				
5.5.				
5.6.				
5.7.	Measuring Results			ł
6.	HARMONIC CURRENT EMISSION ME	EASUREMENT		ļ
6.1.	Block Diagram of Test Setup			L
6.2			24	
6.3.	Operation Condition of EUT			Ĺ
6.4.	Measuring Results			ļ
7.	VOLTAGE FLUCTUATION AND FLICH	KER MEASUREMENT.		J
7.1.	Block Diagram of Test Setup			ł
7.2	Measuring Standard		20	í
7.3.	Operation Condition of EUT		28	í
7.4			28	
8.				
9.				
9.1.	Block Diagram of Test Setup			l
9.2	Test Standard			
9.3.				
9.4.				
9.5.	Test Procedure			ł
TRF	NO. EN61000-6-3/-6-1/-6-2/A	Page 2 of 62	Report No.: EN160824004E Ver.1.0	





9.6.	Test Results	. 32
10. RF FIELD STRENGTH SUSCEPTIBILITY TEST		
10.1.	Block Diagram of Test Setup	34
10.2	Test Standard	- 24
10.3	Severity Levels and Performance Criterion	- 52
10.4	Operating Condition of EUT	
10.5	Test Procedure	
10.6.	Test Results	
11. ELECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST		
11.1.	Block Diagram of Test Setup	. 37
11.2.	Test Standard	
11.3.	Severity Levels and Performance Criterion	37
11.4	Operating Condition of EUT	
11.5	Test Procedure	38
11.6	Test Result	
12. SU	12. SURGE IMMUNITY TEST	
12.1.	Block Diagram of Test Setup	. 40
12.2	Test Standard	. 40
12.3.	Severity Levels and Performance Criterion	. 40
12.4	Operating Condition of EUT	41
12.5	Test Procedure	41
12.6.	Test Result	41
13. INJECTED CURRENTS SUSCEPTIBILITY TEST		
13.1.	Block Diagram of Test Setup	43
13.2	Test Standard	
13.3	Severity Levels and Performance Criterion	43
13.4	Operating Condition of EUT	
13.5	Test Procedure	
13.6	Test Results	
14. MAGNETIC FIELD SUSCEPTIBILITY TEST 46		
14.1.	Block Diagram of Test Setup	
14.2.	Test Standard	. 46
14.3.	Severity Levels and Performance Criterion	. 46
14.4.	EUT Configuration on Test	. 47
14.5	Test Procedure	
14.6.	Test Results	
15 PH	DTOGRAPH	
15.1.	Photo of Conducted Emission Measurement	. 49
15.2.	Photo of Radiation Emission Measurement	
15.3.	Photo of Harmonics and Flicker Test	. 50
15.4.	Photo of RF Field Strength Susceptibility Test	. 51
15.5.	Photo of Surge Test	. 51
15.6.	Photo of injected Currents Susceptibility Test	. 52
15.7.	Photo of Magnetic Field Susceptibility Test	. 52

APPENDIX I (Photos of EUT) (7 Pages) APPENDIX II (Model List) (1 Page)

TRF NO. EN61000-6-3/-6-1/-6-2/A

Page 3 of 62

Report No.: EN160824004E Ver.1.0





TEST REPORT DESCRIPTION

Applicant	E.	SOLAX POWER CO., LTD.
Manufacturer	- ŝ	SOLAX POWER CO., LTD.
Trade Mark	÷	SolaX
EUT	1	X1-Hybrid-single phase
Model No.	1	X1-Hybrid-3.0-N-E, X1-Hybrid-3.0-D-E, X1-Hybrid-3.0-N-I, X1-Hybrid-3.0-D-I, X1-Hybrid-3.0-N-C, X1-Hybrid-3.0-D-C, X1-Hybrid-3.7-N-E, X1-Hybrid-3.7-D-E, X1-Hybrid-3.7-N-I, X1-Hybrid-3.7-D-I, X1-Hybrid-3.7-N-C, X1-Hybrid-3.7-D-C, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-D-E, X1-Hybrid-4.6-N-I, X1-Hybrid-4.6-D-I, X1-Hybrid-4.6-N-C, X1-Hybrid-4.6-D-C, X1-Hybrid-5.0-N-E, X1-Hybrid-5.0-D-E, X1-Hybrid-5.0-N-I, X1-Hybrid-5.0-D-I, X1-Hybrid-5.0-N-C, X1-Hybrid-5.0-D-C

Measurement Procedure Used:

TRE N

EN 61000-6-3:2007+A1:2011 EN 61000-3-12:2011 EN 61000-3-11:2000 EN 61000-3-12:2007, EN 61000-6-2:2005 (EC 61000-4-2:2008, IEC 61000-4-3:2006+A1:2007+A2:2010, IEC 61000-4-4:2012, IEC 61000-4-5:2005, IEC 61000-4-6:2013, IEC 61000-4-8:2009)

The device described above is tested by EMTEK (NINGBO) CO., LTD. to determine the maximum emission levels emanating from the device and the servers levels of the device can endure and its performance criterion. The measurement results are contained in this test report and EMTEK (NINGBO) CO., LTD. is assumed full of responsibility for the accuracy and completeness of these measurements. Also, this report shows that the EUT (Equipment under Test) is technically compliant with the EN 61000-6-3, EN 61000-6-1, EN 61000-6-2, EN 61000-3-12 and EN 61000-3-11 requirements.

This report applies to above tested sample only and shall not be reproduced in part without written approval of EMTEK (NINGBO) CO., LTD.

Date of Test	:	August 24, 2016 to	September 14, 2016	
Prepared by	×.	(End	phia	
Reviewer	100 100 100	(Quality)		
Approved & Authorized	f Signer :	the second se	And Curd	
O. EN61000-6-3/-6-1/-6-2/	'A	Page 4 of 62	Report No.: EN160824004E Ver.1.	0

Copyright @ Bureau Veritas LCIE CHINA



EMTEK

Modified History

Version	Report No.	Revision date	Summary
Ver. 1.0	EN160824004E	3	Original Report

TRF NO. EN51000-6-3/-6-1/-6-2/A

Page 5 of 62

Report No.: EN160824004E Ver.1.0



EMTEK

1. SUMMARY OF TEST RESULT

EMISSION				
Description of Test Item	Standard	Limits	Results	
Conducted Disturbance at Mains Terminals	EN 61000-6-3:2007+A1:2011	Table 2	Pass	
Radiated Disturbance	EN 61000-6-3:2007+A1:2011	Table 1	Pass	
Harmonics"	EN 61000-3-12:2011	Table 3	Pass	
Voltage fluctuation and flicker*	EN 61000-3-11:2000	Section 5	Pass	
IMMUNITY (EN 61000-6-1:2007, EN 61000-6-	2:2005)		
Description of Test Item	Basic Standard	Performance Criteria	Results	
Electrostatic Discharge (ESD)	IEC 61000-4-2:2008	в	Pass	
Radio-Frequency, Continuous Radiated Disturbance*	IEC 61000-4-3:2006+ A1:2007+A2:2010	A	Pass	
EFT/B Immunity	IEC 61000-4-4:2012	в	Pass	
Surge Immunity	IEC 61000-4-5:2005	в	Pass	
Conducted RF Immunity*	IEC 61000-4-6:2013	A	Pass	
Power Frequency Magnetic Field*	IEC 61000-4-8:2009	A	Pass	
Voitage dips*	IEC 61000-4-11:2004	B&C	N/A	
Voitage Interruptions*	120 01000-4-11.2004	с	N/A	
Note: 1. N/A is an abbreviation for Not Applicable. 2. " Tests were not within the accreditation scope of CNAS L6666, and were conducted at EMTEK (SHENZHEN) CO., LTD.				

TRF NO. EN61000-6-3/-6-1/-6-2/A

Page 6 of 62

Report No.: EN160824004E Ver.1.0





2. GENERAL INFORMATION

2.1. Description of Device (EUT)

EUT	: X1-Hybrid-single phase
Model Number	X1-Hybrid-3.D-N-E, X1-Hybrid-3.0-D-E, X1-Hybrid-3.0-N-I, X1-Hybrid-3.0-D-I, X1-Hybrid-3.D-N-C, X1-Hybrid-3.0-D-C, X1-Hybrid-3.7-N-E, X1-Hybrid-3.7-N-E, X1-Hybrid-3.7-N-E, X1-Hybrid-3.7-N-E, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-N-E, X1-Hybrid-4.6-N-E, X1-Hybrid-5.0-N-E, X1-Hybrid-5.0-D-E, X1-Hybrid-5.0-N-E, X1-Hybrid-5.0-D-E, X1-Hybrid-5.0-N-C, X1-Hybrid-5.0-D-C (Note: All models are identical except powers. "3.0" means 3.0kV; "D" means with "DC switch"; "N" means without "DC switch"; "E" means "EPS function" needs to install an external changeover device; "I" means "EPS function" has install an external changeover device already. "C" means without "EPS". We prepared X1-Hybrid-5.0-D-E for EMC tests.)
Power Supply	: Please see APPENDIX II for detail Information
Test voltage	: AC 230V/50Hz or DC 360V (from DC source)
Applicant	: SOLAX POWER CO., LTD.
Address	No. 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing Disctrict, Tonglu City, Zhejlang Province, People's Republic of China
Manufacturer	: SOLAX POWER CO., LTD.
Address	No.288 Shizhu Road, Tonglu Economic Development Zone, Dongxing Disctrict, Tonglu City, Zhejiang Province, People's Republic of China
Date of Received	: August 24, 2016
Date of Test	: August 24, 2016 to September 14, 2016

2.2. Description of Test Facility

Site Description	
EMC Lab.	: Accredited by CNAS, 2014.1.21 The certificate is valid until 2017.1.20
	The Laboratory has been assessed and proved to be in compliance with
	CNAS-CL01:2006 (identical to ISO/IEC 17025:2005) The Certificate Registration Number is L6666.
	Accredited by FCC, June 18, 2014 The Certificate Registration Number is 463622.
Name of Firm Site Location	: EMTEK (NINGBO) CO., LTD. : 1F Building 4, 1177#, Lingyun Road, National Hi-Tech Zone, Ningbo, Zhejlang,
	China

TRF NO. EN61000-6-3/-6-1/-6-2/A

Page 7 of 62

Report No.: EN160824004E Ver.1.0





2.3. Description of Support Device

DC Source : M/N: 62150H-600S Manufacturer: CHROMA S/N: 62150EC00185

2.4. Measurement Uncertainty

Conducted Emission Uncertainty	: 2.8dB
Radiated Emission Uncertainty	: 3.3dB (3m Chamber)
Uncertainty for Filcker test	: 0.07%
Uncertainty for Harmonic test	: 1.8%
Uncertainty for C/S Test	: 1.45(Using CDN Test) 2.37(Using EM Clamp Test)
Uncertainty for R/S Test	: 2.10dB(80MHz-200MHz) 1.76dB(200MHz-1000MHz)

TRF NO. EN61000-6-3/-6-1/-6-2/A

Page 8 of 62

Report No.: EN160824004E Ver.1.0





EMC TEST REPORT

For

SOLAX POWER NETWORK TECHNOLOGY(ZHEJIANG)CO., LTD.

X1-Retro Fit Series

Model No.: X1-Fit-3.7E, X1-Fit-3.7I, X1-Fit-3.7C, X1-Fit-4.6E, X1-Fit-4.6I, X1-Fit-4.6C, X1-Fit-5.0E, X1-Fit-5.0I, X1-Fit-5.0C

Prepared for Address	:	SOLAX POWER NETWORK TECHNOLOGY(ZHEJIANG)CO., LTD. No.288 Shizhu Road, Tongiu Economic Development Zone, Tongiu City, Zhejiang Province, China.
Prepared by Address	-	EMTEK (NINGBO) CO., LTD. 1/F ., Building 4, No. 1177, Lingyun Road, Ningbo National HI-Tech Zone, Ningbo, Zhejlang, China
		Tel: +86-574-27907998 Fax: +86-574-27721538

Report Number	1	EN170828001E
Date of Test	- 2	August 28, 2017 to October 10, 2017
Date of Report	1	October 23, 2017

TRF NO. EN61000-6-3/-6-1/-6-2/A

Page 1 of 64

Report No.: EN170828001E Ver.1.0





TABLE OF CONTENT

TEST REPORT DESCRITION 1. SUMMARY OF TEST RESULT		PAGE
		7
3.9. For Magnetic Field Immunity Te	est.	
3.10. For Voltage Dips and Interrupti	ons Test	
POWER LINE CONDUCTED EMIS	SION MEASUREMENT	
4.1. Block Diagram of Test Setup		
		12
		12
		12
		13
		13
5. RADIATED EMISSION MEASURE	MENT	
•		
8. HARMONIC CURRENT EMISSION	MEASUREMENT	24
6.1. Block Diagram of Test Setup		
6.2. Measuring Standard		
VOLTAGE FLUCTUATION AND FL	LICKER MEASUREMENT	28
7.1. Block Diagram of Test Setup		
7.2. Measuring Standard		28
		28
		28
		30
9.1. Block Diagram of Test Setup		
9.2. Test Standard		
9.4. Operating Condition of EUT		
9.5. Test Procedure		
10. RF FIELD STRENGTH SUSCEPTI	BILITY TEST	
TRF NO. EN61000-8-3/-6-1/-6-2/A	Page 2 of 64	Report No.: EN170828001E Ver.1.0





10.1.	Block Diagram of Test Setup	
10.2	Test Standard	
10.3.	Severity Levels and Performance Criterion	
10.4.	Operating Condition of EUT	
10.5.	Test Procedure	
10.6.	Test Results	
11. EL	ECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST	
11.1.	Block Diagram of Test Setup	
11.2.	Test Standard	
11.3.	Severity Levels and Performance Criterion	
11.4.	Operating Condition of EUT	
11.5.	Test Procedure	
11.6.	Test Result	
12. SU	RGE IMMUNITY TEST	 40
12.1.	Block Diagram of Test Setup	40
12.1.	Test Standard	
12.3	Severity Levels and Performance Criterion	
12.4	Operating Condition of EUT	
12.5	Test Procedure	
12.6.	Test Result	
13. INJ	ECTED CURRENTS SUSCEPTIBILITY TEST	
13.1.	Block Diagram of Test Setup	43
13.2	Test Standard	 43
13.3.	Severity Levels and Performance Criterion	43
13.4.	Operating Condition of EUT	
13.5.	Test Procedure	
13.6.	Test Results	
14. MA	GNETIC FIELD SUSCEPTIBILITY TEST	
14.1.	Block Diagram of Test Setup	46
14.2	Test Standard	
14.3	Severity Levels and Performance Criterion	
14.4.	EUT Configuration on Test	
14.5.	Test Procedure	
14.6.	Test Results	
16. VO	LTAGE DIPS AND INTERRUPTIONS TEST	
15.1.	Block Diagram of Test Setup	
15.2	Test Standard	
15.3.	Severity Levels and Performance Criterion	
15.4.	Operating Condition of EUT	
15.5.	Test Procedure	
15.6.	Test Result	
16, PH	OTOGRAPH	
16.1.	Photo of Conducted Emission Measurement	
16.2	Photo of Radiation Emission Measurement	
16.3.	Photo of Harmonics and Flicker Test	
16.4.	Photo of Electrostatic Discharge Test	
16.5.	Photo of RF Field Strength Susceptibility Test	
16.6.	Photo of Surge Test	
16.7.	Photo of Injected Currents Susceptibility Test	
16.8.	Photo of Magnetic Field Susceptibility Test	
16.9	Photo of Voltage Dips and Interruption Immunity Test	56

APPENDIX I (Photos of EUT) (5 Pages) APPENDIX II (Model List) (1 Page)

TRF NO. EN61000-8-3/-8-1/-8-2/A

Page 3 of 64

Report No.: EN170828001E Ver.1.0





TEST REPORT DESCRIPTION

Applicant	:	SOLAX POWER NETWORK TECHNOLOGY(ZHEJIANG)CO., LTD.
Manufacturer	:	SOLAX POWER NETWORK TECHNOLOGY(ZHEJIANG)CO., LTD.
Trade Mark	:	SolaX
EUT	:	X1-Retro Fit Series
Model No.	1	X1-FIt-3.7E, X1-FIt-3.7I, X1-FIt-3.7C, X1-FIt-4.6E, X1-FIt-4.6I, X1-FIt-4.6C, X1-FIt-5.0E, X1-FIt-5.0I, X1-FIt-5.0C

Measurement Procedure Used:

EN 61000-6-3:2007+A1:2011 EN 61000-3-12:2011 EN 61000-3-11:2000 EN 61000-6-1:2007, EN 61000-6-2:2005 (IEC 61000-4-2:2008, IEC 61000-4-3:2006+A1:2007+A2:2010, IEC 61000-4-4:2012, IEC 61000-4-5:2005, IEC 61000-4-6:2013, IEC 61000-4-8:2009, IEC 61000-4-11:2004)

The device described above is tested by EMTEK (NINGBO) CO., LTD. to determine the maximum emission levels emanating from the device and the severe levels of the device can endure and its performance criterion. The measurement results are contained in this test report and EMTEK (NINGBO) CO., LTD. Is assumed full of responsibility for the accuracy and completeness of these measurements. Also, this report shows that the EUT (Equipment under Test) is technically compliant with the EN 61000-6-3, EN 61000-6-1, EN 61000-6-2, EN 61000-3-12 and EN 61000-3-11 requirements.

This report applies to above tested sample only and shall not be reproduced in part without written approval of EMTEK (NINGBO) CO., LTD.

Date of Test	÷ .	August 28, 2017 to October 10, 2017		
Prepared by	:	Saphia (Engineer)		
Reviewer	:	(Quality Manager)		
Approved & Authorized Signer	r:	(Quality Manager) Torry Wei (Manager) (Manager)		

TRF NO. EN81000-8-3/-8-1/-8-2/A

Page 4 of 64

Report No.: EN170828001E Ver.1.0

Copyright © Bureau Veritas LCIE CHINA





Modified History

Version	Report No.	Revision date	Summary
Ver.1.0	EN170828001E	1	Original Report

TRF NO. EN61000-8-3/-8-1/-8-2/A

Page 5 of 64

Report No.: EN170828001E Ver.1.0





1. SUMMARY OF TEST RESULT

EMISSION						
Description of Test Item	Standard	Limits	Results			
Conducted Disturbance at Mains Terminals	EN 61000-6-3:2007+A1:2011	Table 2	Pass			
Radiated Disturbance	EN 61000-6-3:2007+A1:2011	Table 1	Pass			
Harmonics*	EN 61000-3-12:2011	Table 3	Pass			
Voltage fluctuation and flicker*	EN 61000-3-11:2000	Section 5	Pass			
IMMUNITY (EN 81000-8-1:2007, EN 81000-8-2:2005)						
Description of Test Item	Basic Standard	Performance Criteria	Results			
Electrostatic Discharge (ESD)	IEC 61000-4-2:2008	в	Pass			
Radio-Frequency, Continuous Radiated Disturbance"			Pass			
EFT/B immunity*	IEC 61000-4-4:2012	в	Pass			
Surge Immunity"	IEC 61000-4-5:2005	в	Pass			
Conducted RF Immunity"	IEC 61000-4-6:2013	*	Pass			
Power Frequency Magnetic Fleid	IEC 61000-4-8:2009	۸	Pass			
Voltage dips*		B&C	Pass			
Voltage interruptions*	IEC 61000-4-11:2004	с	Pass			

TRF NO. EN61000-8-3/-8-1/-8-2/A

Page 6 of 64

Report No.: EN170828001E Ver.1.0





2. GENERAL INFORMATION

2.1. Description of Device (EUT)

EUT	: X1-Retro Fit Series
Model Number	: X1-FIt-3.7E, X1-FIt-3.7I, X1-FIt-3.7C, X1-FIt-4.6E, X1-FIt-4.6I, X1-FIt-4.6C, X1-FIt-5.0E, X1-FIt-5.0I, X1-FIt-5.0C (Note: The tests were performed under the Grid-ON mode and AC charging mode. The tests were performed with the battery module (manufacturer: Pylon Technologies Co., Ltd., model H48050A-15S) and battery manager system (manufacturer: Pylon Technologies Co., Ltd., model SC0500A-100S). We prepared X1-FIt-5.0I for EMC tests.)
Power Supply	: Please see APPENDIX II(Model List) for detail information
Test voltage	: AC 230V/50Hz or DC 360V (from DC source)
Applicant	: SOLAX POWER NETWORK TECHNOLOGY(ZHEJIANG)CO., LTD.
Address	: No.288 Shizhu Road, Tonglu Economic Development Zone, Tonglu City, Zhejlang Province, China.
Manufacturer	: SOLAX POWER NETWORK TECHNOLOGY(ZHEJIANG)CO., LTD.
Address	: No.288 Shizhu Road, Tonglu Economic Development Zone, Tonglu City, Zhejiang Province, China.
Date of Received	: August 28, 2017
Date of Test	: August 28, 2017 to October 10, 2017

2.2. Description of Test Facility

Site Description	
EMC Lab.	: Accredited by CNAS, 2016.12.20
	The certificate is valid until 2023.1.20
	The Laboratory has been assessed and proved to be in compliance with
	CNAS-CL01:2006 (identical to ISO/IEC 17025:2005)
	The Certificate Registration Number is L6666.
	Accredited by Industry Canada, November 14, 2016
	The Certificate Registration Number is 46405-9469.
Name of Firm	: EMTEK (NINGBO) CO., LTD.
Site Location	: 1F Building 4, 1177#, Lingyun Road, National Hi-Tech Zone, Ningbo, Zhejiang,
	China

2.3. Description of Support Device

:	M/N: 62150H-6008
	Manufacturer: CHROMA
	8/N: 62150EC00185

TRF NO. EN61000-8-3/-8-1/-8-2/A

DC Source

Page 7 of 64

Report No.: EN170828001E Ver.1.0





2.4. Measurement Uncertainty

Conducted Emission Uncertainty	: 3.06dB (9K-150KHz) 2.44dB (150K-30MHz)
Radiated Emission Uncertainty (3m Chamber)	: 3.44dB (Polarize: H) (30MHz-1000MHz) 3.78dB (Polarize: V) (30MHz-1000MHz)
Uncertainty for Flicker test	: 0.07%
Uncertainty for Harmonic test	: 1.8%
Uncertainty for C/S Test	: 1.45(Using CDN Test) 2.37(Using EM Clamp Test)
Uncertainty for R/S Test	: 2.10dB(80MHz-200MHz) 1.76dB(200MHz-1000MHz)

TRF NO. EN61000-8-3/-8-1/-8-2/A

Page 8 of 64

Report No.: EN170828001E Ver.1.0



Annex 2 **Pictures of the unit**







Enclosure left view for all model



Enclosure right view for all model





Enclosure top view for all model



Enclosure bottom view for X1-Hybrid-3.0-N-E, X1-Hybrid-3.7-N-E, X1-Hybrid-4.6-N-E, X1-Hybrid-5.0-N-E







Enclosure bottom view for X1-Hybrid-3.0-D-E, X1-Hybrid-3.7-D-E, X1-Hybrid-4.6-D-E, X1-Hybrid-5.0-D-E Enclosure bottom view for X1-Fit-3.7E,X1-Fit-5.0E

Page 54 of 65



Annex 3

Test Equipment list



No,	Equipment	Internal No,	Type/characteristics	Manufacturer	Last Calibration	Due Data
1	Oscilloscope	A4089024SH	P4034B	Tektronix	26/Jul/18	25/Jul/19
2	Oscilloscope	A4089008SH	DPO3014	Tektronix	23/Jan/19	22/Jan/20
3	Oscilloscope	A4089036SH	DL850	YOKOGAWA	29/Aug/18	28/Aug/19
4	High Voltage probe	A4089026SH	P5200A	Tektronix	23/Jan/19	22/Jan/20
5	Voltage probe	A4089004SH	P2220	Tektronix	10/Oct/18	09/Oct/19
6	Current probe	A4089009SH	P6139B	Tektronix	23/Jan/19	22/Jan/20
7	Current probe	A4089013SH	A622	Tektronix	23/Jan/19	22/Jan/20
8	Current probe	A4089037SH	960 30	YOKOGAWA	10/Oct/18	09/Oct/19
9	Current probe	A4089038SH	960 30	YOKOGAWA	10/Oct/18	09/Oct/19
10	Current probe	A4089039SH	960 30	YOKOGAWA	10/Oct/18	09/Oct/19
11	Current probe	A4089017SH	TCP0150	Tektronix	26/Jul/18	25/Jul/19
12	AC power supply	A7040066SH	AFC-31010T	APC	08/Aug/18	31/Jul/20
13	AC power supply	A7040071SH	29/May/68	Chroma	22/Feb/18	21/Feb/20
14	AC power supply	A7040057SH	29/May/68	Chroma	19/Jul/17	18/Jul/19
15	AC power supply	A7040077SH	MX-30	AMETEK	-	-
16	Programmabl e DC source	A7040058SH	62150H-1000S	Chroma	-	-
17	Programmabl e DC source	A7040059SH	62150H-1000S	Chroma	-	-
18	Programmabl e DC source	A7040069SH	62150H-1000S	Chroma	-	-
19	Programmabl e DC source	A7040074SH	62150H-1000S	Chroma	-	-
20	Programmabl e DC source	A7040075SH	62150H-1000S	Chroma	-	-



Page 65 of 65

-	CIE					
21	Programmable DC source	A7040076SH	62150H-1000S	Chroma	-	-
22	Programmable DC source	A7040070SH	62150H-1000S	Chroma	-	-
23	Power Analyzer	A1240096SH	WT3000	YOKOGAWA	31/Oct/18	30/Oct/19
24	Power Analyzer	A1240097SH	WT3000	YOKOGAWA	06/May/19	05/May/20
25	Power Analyzer	A1240103SH	LMG500	ZES ZIMMER	26/Jul/18	25/Jul/19
26	Power Analyzer	A1240101SH	WT3000	YOKOGAWA	26/Jul/18	25/Jul/19
27	Anti-isolating test stystem	A7150074SH	ACTL-380SH	qunling	-	-
28	Load cabinet	A7150083SH	WSTF-LDJ60K/300	shanghai wen shun	-	-
29	Load cabinet	A7150084SH	WSTF-LDJ45K/0385	shanghai wen shun	-	-
30	Load cabinet	A7150085SH	WSTF-LDJ45K/0385	shanghai wen shun	-	-
31	Load cabinet	A7150075SH	WSTF-RC25k/0,3D 0,001kVA-25kVA	shanghai wen shun	-	-
32	Temperature recorder	A740037SH	G820	GRAPHIEC	10/Oct/18	09/Oct/19
33	Load cabinet(for flick)	A7150090SH	200Ω ,250V;1200W	shanghai wen shun	-	-
34	Variable resistor	A7150076SH	BX8-67	LingOu	-	-