



APPROVALS®

## Certificate of Suitability

**Certificate No.:** SAA161831

**Certificate Holder:** Solax Power Co., Ltd.  
No. 288 Shizhu Road,  
Tonglu Economic Development Zone,  
Dongxing District, Tonglu City,  
Zhejiang Province,  
P.R. China

**Class Description:** Non-Declared  
**Product Description:** PV Inverter  
**Brand Name:** Solax (logo)  
**Model No.:** X1-3.3-S-D  
**Markings:** Input: 100-600Vdc, MPPT range 100-580Vdc,  
10A Max, Isc 12A  
Output: 220/230/240V~ 50/60Hz 15A Max, 3300VA  
ta:60°C, Class I, IP65

**Standard:** IEC 62109-1 Ed 1.0  
IEC 62109-2 Ed 1.0  
AS/NZS 4777.2:2015

**Conditions:** Nil

**Certification Mark:** SAA161831 or RCM

**Date First Registered:** 7 September 2016

**Date of Expiry:** 7 September 2021


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 12-09-16 161831/1a  
Ratings amended



APPROVALS®

# Certificate of Suitability

**\*Addendum\***

**Certificate No.:** SAA161831

**Date of Issue:** 7 September 2016

**Class Description:** Non-Declared  
**Product Description:** PV Inverter

<b>Additional Models</b>	<b>Description</b>
X1-1.1-S-D	Similar to X1-3.3-S-D except rated: Input: 70-400Vdc, MPPT range 70-380Vdc, 10A Max, Isc 12A Output: 220/230/240V~ 50/60Hz 5.5A Max, 1100VA
X1-1.1-S-N	Similar to X1-1.1-S-D except without dc switch.
X1-1.5-S-D	Similar to X1-3.3-S-D except rated: Input: 70-400Vdc, MPPT range 70-380Vdc, 10A Max, Isc 12A Output: 220/230/240V~ 50/60Hz 7.5A Max, 1500VA
X1-1.5-S-N	Similar to X1-1.5-S-D except without dc switch.
X1-2.0-S-D	Similar to X1-3.3-S-D except rated: Input: 70-400Vdc, MPPT range 70-380Vdc, 10A Max, Isc 12A Output: 220/230/240V~ 50/60Hz 9.5A Max, 2000VA
X1-2.0-S-N	Similar to X1-2.0-S-D except without dc switch.
X1-2.5-S-D	Similar to X1-3.3-S-D except rated: Input: 100-600Vdc, MPPT range 100-580Vdc, 10A Max, Isc 12A Output: 220/230/240V~ 50/60Hz 12A Max, 2500VA
X1-2.5-S-N	Similar to X1-2.5-S-D except without dc switch.
X1-3.0-S-D	Similar to X1-3.3-S-D except rated: Input: 100-600Vdc, MPPT range 100-580Vdc, 10A Max, Isc 12A Output: 220/230/240V~ 50/60Hz 14A Max, 3000VA
X1-3.0-S-N	Similar to X1-3.0-S-D except without dc switch.
X1-3.3-S-N	Similar to X1-3.3-S-D except without dc switch.


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 12-09-16 161831/2a  
Ratings amended