



BV LCIE
CHINA
Number

N°1666AS08SXP21958

ATTESTATION of conformity with European Directives

Product: **Grid-tied photovoltaic inverter**
Reference **X1-3.0-T-D, X1-3.0-T-N, X1-3.3-T-D, X1-3.3-T-N, X1-3.6-T-D,
X1-3.6-T-N, X1-4.2-T-D, X1-4.2-T-N, X1-4.6-T-D, X1-4.6-T-N.**
Issued to **SOLAX POWER CO., LTD**
Address **No. 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing
District 311500, Tonglu City, Zhejiang Province, People's Republic of
China**
Manufacturer **SolaX Power Co., Ltd**
Technical characteristics **See Next Page**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

| <i>Standards</i> | <i>Report number</i> | <i>Report date</i> |
|-------------------------|---------------------------|--------------------|
| EN 62109-1: 2010 | SXP-16AU2123FTSP-1 | 31/08/2016 |
| EN 62109-2: 2011 | SXP-16AU2123FTSP-2 | 31/08/2016 |

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China),), Aug 31th, 2016.



Dio Zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有
限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



LCIE

BV LCIE
CHINA
Number

N°1666AS08SXP21958

| | | | |
|---------------------------------|-----------------------------|-----------------------------|-----------------------------|
| Model / Type | X1-3.0-T-D, X1-3.0-T-N | X1-3.3-T-D, X1-3.3-T-N | X1-3.6-T-D, X1-3.6-T-N |
| Ratings | See below | See below | See below |
| MPP DC voltage range [V] | 125-580 | 125-580 | 125-580 |
| Input DC voltage range [V]..... | 125-600 | 125-600 | 125-600 |
| Input DC current [A]..... | 12/12 | 12/12 | 12/12 |
| Output AC voltage [V]..... | 220/230/240 Vac, 50/60Hz | 220/230/240 Vac, 50/60Hz | 220/230/240 Vac, 50/60Hz |
| Max.Output AC current [A]..... | 14 | 15 | 16 |
| Output power [VA] | 3000 | 3300 | 3680 |

| | | | |
|---------------------------------|-----------------------------|-----------------------------|----|
| Model / Type | X1-4.2-T-D, X1-4.2-T-N | X1-4.6-T-D, X1-4.6-T-N | -- |
| Ratings | See below | See below | -- |
| MPP DC voltage range [V] | 125-580 | 125-580 | -- |
| Input DC voltage range [V]..... | 125-600 | 125-600 | -- |
| Input DC current [A]..... | 12/12 | 12/12 | -- |
| Output AC voltage [V]..... | 220/230/240 Vac, 50/60Hz | 220/230/240 Vac, 50/60Hz | -- |
| Max.Output AC current [A]..... | 19 | 21 | -- |
| Output power [VA] | 4200 | 4600 | -- |

Shanghai (P.R. China),), Aug 31th, 2016.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com

Version 3/2016.02.19