



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA132269

Date of Issue: 24 February 2015

Class Description: Non-Declared
Product Description: Grid-Connected Photovoltaic Inverter

General Modification:

Updated to comply with AS/NZS 3100:2009 Inc A1-3.

Additional Models	Description
SK-SU5000E	Similar to SK-SU5000 except for model number.
SK-SU3700E	Similar to SK-SU5000 except rated Max input 4000W and output 16A 3680VA.
SK-SU3000E	Similar to SK-SU5000 except rated Max input 12A 3300W and output 14.4A 3000VA.
SK-SU5000C	Similar to SK-SU5000 except for model number.
SK-SU3700C	Similar to SK-SU5000 except rated Max input 4000W and output 16A 3680VA.
SK-SU3000C	Similar to SK-SU5000 except rated Max input 12A 3300W and output 14.4A 3000VA.
SK-TL5000E	Similar to SK-SU5000 except for model number.
SK-TL3700E	Similar to SK-SU5000 except rated Max input 4000W and output 16A 3680VA.
SK-TL3000E	Similar to SK-SU5000 except rated Max input 12A 3300W and output 14.4A 3000VA.
SK-TL5000C	Similar to SK-SU5000 except for model number.
SK-TL3700C	Similar to SK-SU5000 except rated Max input 4000W and output 16A 3680VA.
SK-TL3000C	Similar to SK-SU5000 except rated Max input 12A 3300W and output 14.4A 3000VA.
SK-TL5000R	Similar to SK-SU5000 except for model number.
SK-TL3700R	Similar to SK-SU5000 except rated Max input 4000W and output 16A 3680VA.
SK-TL3000R	Similar to SK-SU5000 except rated Max input 12A 3300W and output 14.4A 3000VA.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 03-03-15 132269/3a
Model number corrected



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA132269

Date of Issue: 24 February 2015


Class Description: Non-Declared
Product Description: Grid-Connected Photovoltaic Inverter

Additional Models	Description
SK-BMU1300	Battery management unit which has independent battery charging and discharging circuit and can be used with SK-SU5000, SK-SU3700, SK-SU3000, SK-TL5000, SK-TL3700 or SK-TL3000. Rated:- Battery type: Lithium or Lead-acid Battery Rated voltage: 48Vdc Battery operation voltage: 40-58Vdc Max current: 15A Max power: 1300W Bus Voltage Range: 360-550Vdc Max Bus Current: 15A Indoor use only
SK-BMU5000	Similar to SK-BMU1300 except rated Battery operation voltage: 40-60Vdc, Max 100A 5000W.
SK-BMU5000R	Similar to SK-BMU1300 except rated Battery operation voltage: 40-60Vdc, Max 100A 5000W, Bus Voltage range: 360-550Vdc, Max Bus Current 15A.
SK-BMU2500	Similar to SK-BMU1300 except rated Battery operation voltage: 40-60Vdc, Max 50A 2500W, Bus Voltage range: 360-550Vdc, Max Bus Current 15A.
SK-BMU2500R	Similar to SK-BMU1300 except rated Battery operation voltage: 40-60Vdc, Max 50A 2500W, Bus Voltage range: 360-550Vdc, Max Bus Current 15A.
SK-BMU1300II	Similar to SK-BMU1300 except for model number.
SK-BMU1300R	Similar to SK-BMU1300 except for model number.

For and on Behalf of
SAA Approvals Pty Ltd



SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.



For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

www.jas-anz.org/register

Issued: 24-02-15 132269/4



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA132269

Date of Issue: 4 August 2016

Class Description: Non-Declared

Product Description: Grid-Connected Photovoltaic Inverter

General Modification:

Updated to comply with AS/NZS 4777.2:2015.

For models SK-SU3000E, SK-SU3000C, SK-TL3000E and SK-TL3000C:
Changed from single PV string to two PV strings and rated 12/12Adc.

Additional Models	Description
SK-SU3000E-S	Similar to SK-SU3000E except for model number.
SK-SU3000C-S	Similar to SK-SU3000C except for model number.
SK-TL3000E-S	Similar to SK-TL3000E except for model number.
SK-TL3000C-S	Similar to SK-TL3000C except for model number.
SK-TL3000R-S	Similar to SK-TL3000R except for model number.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 04-08-16 132269/5



4 August 2016

Solax Power Co., Ltd.
No. 288 Shizhu Road,
Tonglu Economic Development Zone,
Dongxing District, Tonglu City,
Zhejiang Province,
P.R. China

C/- TUV SUD Certification and Testing (China) Co., Ltd. Shanghai Branch

Dear Sir

**Modification to Certificate – SAA132269
Grid-Connected Photovoltaic Inverter
Model No.: SK-SU5000**

We hereby advise that your application for modification to the above electrical product has been accepted.

The enclosed certificate should be stored with the original certificate as evidence of certification.

As a reminder please note that all products approved under this certificate must be marked with the SAA Number SAA132269 or may be marked with the Regulatory Compliance Mark (RCM). The RCM must be used in accordance with the conditions set out in the relevant parts of AS/NZS 4417.

If you need any further information or need to discuss this letter please don't hesitate to contact our office.

Yours sincerely

A handwritten signature in black ink, appearing to be a stylized 'S' or similar character.

**For and on behalf of
SAA Approvals Pty Ltd**

ABN 91 125 451 327

P. +61 7 3393 9455

F. +61 7 3393 9499

E. info@saaapprovals.com.au

W. www.saaapprovals.com.au

PO Box 189, Cannon Hill QLD 4170
5/20 Rivergate Place, Murarrie QLD 4172