



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA121712

Certificate Holder: Solax Power Co., Ltd.
No. 288 Shizhu Road,
Tonglu Economic Development Zone,
Dongxing District 311500, Tonglu City,
Zhejiang Province,
P.R. China

Class Description: Non-Declared
Product Description: Grid-tied PV Inverter
Brand Name: Solax Power
Model No.: ZDNY-TL17000
Markings: Input: Max 1000Vdc MPP voltage range: 250-800Vdc
input A 22A/input B 22A
Output: 400V~ 3/N/PE 50Hz, Max 3x25A 17000W
-20°C - +60°C, IP54 (Fans), IP65 (Other)

Standard: AS 4777.2:2005
AS 4777.3:2005
AS/NZS 3100:2009 Inc A1

Conditions: Nil

Approval Mark: SAA121712 or RCM

Date First Registered: 3 September 2012


Date of Expiry: 3 September 2017

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 03-03-15 121712/1a
Transferred to new Certificate holder and
trade name changed



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA121712

Date of Issue: 3 September 2012

Class Description: Non-Declared
Product Description: Grid-tied PV Inverter

Additional Models

ZDNY-TL15000

ZDNY-TL12000

ZDNY-TL10000

Description

Similar to ZDNY-TL17000 except rated output Max 3x24A 15000W.

Similar to ZDNY-TL17000 except rated input A 22A/input B 11A and output Max 3x20A 12000W.

Similar to ZDNY-TL17000 except rated input A 22A/input B 11A and output Max 3x16A 10000W.


A handwritten signature in black ink, appearing to be 'J. Smith', written over a horizontal line.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 03-03-15 121712/2a
Reissued to Certificate of Suitability



Certificate of Suitability

Addendum

Certificate No.: SAA121712

Date of Issue: 3 March 2015

Class Description: Non-Declared
Product Description: Grid-tied PV Inverter

General Modification:

Updated to comply with AS/NZS 3100:2009 Inc A1-3, IEC 62109-1 Ed 1.0 and IEC 62109-2 Ed 1.0.

| Additional Models | Description |
|--------------------------|---|
| ZDNY-TL20000 | Similar to ZDNY-TL17000 except rated output Max 3x29A 20000W. |

A handwritten signature in dark ink, appearing to be 'DL', is written over a horizontal line.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



Issued: 03-03-15 121712/3



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA121712

Date of Issue: 30 January 2017

Class Description: Non-Declared

Product Description: Grid-tied PV Inverter

General Modification:

Updated to comply with AS/NZS 4777.2:2015.

A handwritten signature in black ink, appearing to be 'J. Smith', positioned above a horizontal line.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 30-01-17 121712/4