



**BUREAU
VERITAS**

Świadectwo zgodności

Zgłaszający: **SolaX power Co., Ltd.**
No. 288 Shizhu Road, Tonglu Economic Development Zone,
Dongxing District 311500, Tonglu City, Zhejiang Province,
China

Produkt: **Siatka wiązanej fotowoltaicznych (PV) falownik**

Model: **X1-1.1-S-D, X1-1.1-S-N, X1-1.5-S-D, X1-1.5-S-N,
X1-2.0-S-D, X1-2.0-S-N, X1-2.5-S-D, X1-2.5-S-N,
X1-3.0-S-D, X1-3.0-S-N, X1-3.3-S-D, X1-3.3-S-N**

Zastosowanie zgodnie z przepisami:

Automatyczne urządzenie wyłączające, monitorujące sieć jednofazową w systemach fotowoltaicznych z obwodem równoległym jednofazową poprzez przetwornicę w publicznej sieci zasilania. Automatyczne urządzenie wyłączające stanowi część wyżej wymienionej przetwornicy.

Zastosowane przepisy i normy:

EN 50438:2013, PN-EN 50438:2014

Wymagania dla instalacji mikrogeneracyjnych przeznaczonych do równoległego przyłączenia do publicznych sieci dystrybucyjnych niskiego napięcia

DIN V VDE V 0126-1-1:2006-02 (bezpieczeństwo funkcjonalne)

Automatyczne urządzenie odłączające między generatorem a publiczną siecią niskiego napięcia

W momencie wydania niniejszego certyfikatu pojęcie zabezpieczenia interfejsu wyżej wymienionego, reprezentatywnego produktu spełnia wymagania bezpieczeństwa obowiązujące dla określonego zastosowania zgodnie z przepisami.

Numer raportu: **SXP-16JY2393FTSP**

Numer świadectwa: **U17-0085**

Data wydania: **2017-03-14**



Instytut certyfikacji Bureau Veritas Consumer Products Services Germany GmbH
Akredytowane zgodnie z normą DIN EN ISO/IEC 17065

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Type Approval and declaration of compliance with the requirements of EN 50438.

Manufacturer / applicant:	SolaX power Co., Ltd. No. 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing District 311500, Tonglu City, Zhejiang Province, China					
Micro-generator Type	Grid-tied photovoltaic inverter					
Rated values	X1-1.1-S-D, X1-1.1-S-N	X1-1.5-S-D, X1-1.5-S-N	X1-2.0-S-D, X1-2.0-S-N	X1-2.5-S-D, X1-2.5-S-N	X1-3.0-S-D, X1-3.0-S-N	X1-3.3-S-D, X1-3.3-S-N
Maximum rated capacity	1100 VA	1500 VA	2000 VA	2500 VA	3000 VA	3300 VA
Rated voltage	220/230/240 Vac, 50/60Hz					
Firmware version	V 3.08					
Measurement period:	2016-12-29 to 2017-02-20					

Description of the structure of the power generation unit (Figure 1):

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.




Figure 1 – Schematic structure of the power generation unit

The above stated micro-generators are tested according to the requirements in the EN 50438. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the EN 50438.

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Type testing of the interface protection

Over-/under-voltage tests						
X1-2.0-S-D						
Parameter	Protection limit		Actual setting		Trip value (test result)	
	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]
Over-voltage stage 1	253,0	3,0	253,0	3,0	251,5	1,351
Over-voltage stage 2	264,5	0,2	264,5	0,2	264,8	0,174
Under-voltage stage 1	195,5	1,5	195,5	1,5	195,3	1,356
X1-3.3-S-D						
Parameter	Protection limit		Actual setting		Trip value (test result)	
	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]
Over-voltage stage 1	253,0	3,0	253,0	3,0	254,6	1,350
Over-voltage stage 2	264,5	0,2	264,5	0,2	263,2	0,178
Under-voltage stage 1	195,5	1,5	195,5	1,5	194,0	1,354
Note. Minimum operation time according to default interface protection: Over-voltage stage 1 - Over-voltage stage 2 0,1s Under-voltage 1,2s						

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Over-/under-frequency tests						
X1-2.0-S-D						
Parameter	Protection limit		Actual setting		Trip value (test result)	
	Frequency [Hz]	Disconnection time [s]	Frequency [Hz]	Disconnection time [s]	Frequency [Hz]	Disconnection time [s]
Over-frequency	52,0	0,5	52,0	0,5	52,01	0,424
Under-frequency	47,5	0,5	47,5	0,5	47,51	0,420
X1-3.3-S-D						
Parameter	Protection limit		Actual setting		Trip value (test result)	
	Frequency [Hz]	Disconnection time [s]	Frequency [Hz]	Disconnection time [s]	Frequency [Hz]	Disconnection time [s]
Over-frequency	52,0	0,5	52,0	0,5	52,01	0,428
Under-frequency	47,5	0,5	47,5	0,5	47,50	0,420
Note. Minimum operation time according to default interface protection: Over-frequency 0,5 s Under-frequency 0,5 s						

LoM test						
X1-2.0-S-D						
Method used	EN 62116					
Balancing load on islanded network	33% of -5% Q Test 22	66% of -5% Q Test 12	100% of -5% P Test 5	33% of +5% Q Test 31	66% of +5% Q Test 21	100% of +5% P Test 10
Trip time. Phase 1 fuse removed [ms]	244,7	276,7	300,7	180,7	168,7	228,7
X1-3.3-S-D						
Method used	EN 62116					
Balancing load on islanded network	33% of -5% Q Test 22	66% of -5% Q Test 12	100% of -5% P Test 5	33% of +5% Q Test 31	66% of +5% Q Test 21	100% of +5% P Test 10
Trip time. Phase 1 fuse removed [ms]	209,0	207,5	198,0	170,0	135,5	158,0
Indicate additional shut down time included in above results. (Integrated interface switch)				Type of switching equipment 1: Relay Type of switching equipment 2: Relay		

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Type testing of a micro-generator

Operating range

Test 1: U = 195,5 V; f = 47,5 Hz; P = 1,00 Sn; cosφ = 1

Test 2: U = 253,0 V; f = 51,5 Hz; P = 1,00 Sn; cosφ = 1

X1-2.0-S-D

Test sequence	Voltage [V]	Frequency [Hz]	Output power [W]	Cos φ [1]
1	195,4	47,5	1,998	0,998
2	253,1	51,5	1,996	0,998

X1-3.3-S-D

Test sequence	Voltage [V]	Frequency [Hz]	Output power [W]	Cos φ [1]
1	195,6	47,5	2,971	0,999
2	253,1	51,5	3,285	0,999

Active power at under-frequency

X1-2.0-S-D

5-min mean value (each)	a) 50 ± 0,01 [Hz]	b) - 0,4 to - 0,5 [Hz]	c) - 2,4 to - 2,5 [Hz]
Frequency [Hz]:	50,00	49,50	47,55
Active power [kW]:	1,985	1,979	1,977
ΔP/PM [%] per 1 Hz:			0

X1-3.3-S-D

5-min mean value (each)	a) 50 ± 0,01 [Hz]	b) - 0,4 to - 0,5 [Hz]	c) - 2,4 to - 2,5 [Hz]
Frequency [Hz]:	50,00	49,50	47,55
Active power [kW]:	3,266	3,207	3,199
ΔP/PM [%] per 1 Hz:			2,03

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Power response to over-frequency							
X1-2.0-S-D							
1-min mean value [Hz]:	a) 50,00	b) 50,25	c) 50,70	d) 51,15	e) 50,70	f) 50,25	g) 50,00
1. Measurement a) to g): Active power output > 80% P _n							
Frequency [Hz]:	50,00	50,25	50,70	51,15	50,70	50,25	50,00
PM [kW]:	N/A	1,960	1,600	1,240	1,600	1,960	N/A
PE60 [kW]:	2,018	1,971	1,563	1,219	1,564	1,910	2,008
ΔPE60/PM [%]:	N/A	+0,56	-2,31	-1,69	-2,25	-2,55	N/A
2. Measurement a) to g): Active power output 40% and 60% after freezing > 80% P _n							
Frequency [Hz]:	50,00	50,25	50,70	50,15	50,70	50,25	50,00
PM [kW]:	N/A	0,980	0,800	0,620	0,800	0,980	N/A
PE60 [kW]:	1,013	0,950	0,806	0,633	0,779	0,952	1,013
ΔPE60/PM [%]:	N/A	-3,00	+0,60	+1,30	-0,10	-2,8	N/A
Limit ΔP/P1min:	+ 10 % of P _M						
X1-3.3-S-D							
1-min mean value [Hz]:	a) 50,00	b) 50,25	c) 50,70	d) 51,15	e) 50,70	f) 50,25	g) 50,00
1. Measurement a) to g): Active power output > 80% P _n							
Frequency [Hz]:	50,00	50,25	50,70	51,15	50,70	50,25	50,00
PM [kW]:	N/A	3,234	2,640	2,046	2,640	3,234	N/A
PE60 [kW]:	3,214	3,145	2,551	1,961	2,541	3,145	3,214
ΔPE60/PM [%]:	N/A	-2,69	-2,70	-2,58	-3,00	-2,70	N/A
2. Measurement a) to g): Active power output 40% and 60% after freezing > 80% P _n							
Frequency [Hz]:	50,00	50,25	50,70	50,15	50,70	50,25	50,00
PM [kW]:	N/A	1,617	1,320	1,023	1,320	1,617	N/A
PE60 [kW]:	1,623	1,558	1,295	1,003	1,285	1,524	1,623
ΔPE60/PM [%]:	N/A	-3,58	+1,52	+1,21	-2,12	-5,64	N/A
Limit ΔP/P1min:	+ 10 % of P _M						

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Reactive power			
Uncontrollable reactive power			
X1-1.1-S-D			
Test Voltage	211,6V	230V	248,4V
Output power			
25% PN	0,9764	0,9762	0,9764
50% PN	0,9953	0,9944	0,9942
75% PN	0,9971	0,9973	0,9970
100% PN	0,9983	0,9980	0,9985
Limit	>0,95	>0,95	>0,95
X1-1.5-S-D			
Test Voltage	211,6V	230V	248,4V
Output power			
25% PN	0,9897	0,9896	0,9897
50% PN	0,9973	0,9972	0,9973
75% PN	0,9985	0,9980	0,9986
100% PN	0,9989	0,9988	0,9984
Limit	>0,95	>0,95	>0,95
X1-2.0-S-D			
Test Voltage	211,6V	230V	248,4V
Output power			
25% PN	0,9939	0,9928	0,9920
50% PN	0,9979	0,9976	0,9976
75% PN	0,9986	0,9982	0,9986
100% PN	0,9987	0,9984	0,9988
Limit	>0,95	>0,95	>0,95
X1-2.5-S-D			
Test Voltage	211,6V	230V	248,4V
Output power			
25% PN	0,9961	0,9962	0,9964
50% PN	0,9989	0,9984	0,9979
75% PN	0,9991	0,9993	0,9989
100% PN	0,9993	0,9998	0,9990
Limit	>0,95	>0,95	>0,95
X1-3.0-S-D			
Test Voltage	211,6V	230V	248,4V
Output power			
25% PN	0,9899	0,9990	0,9897
50% PN	0,9989	0,9992	0,9993
75% PN	0,9989	0,9998	0,9989
100% PN	0,9992	0,9998	0,9998
Limit	>0,95	>0,95	>0,95
X1-3.3-S-D			
Test Voltage	211,6V	230V	248,4V
Output power			
25% PN	0,9981	0,9981	0,9975
50% PN	0,9996	0,9995	0,9994
75% PN	0,9998	0,9998	0,9997
100% PN	0,9998	0,9998	0,9998
Limit	>0,95	>0,95	>0,95

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP


Controllable reactive power				
X1-2.0-S-D				
Inductive (supply reactive power)				
Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ)	AC voltage [V]
0% - 10%	0,176	-1,038	0,167	230,16
10% - 20%	0,383	-1,037	0,346	230,09
20% - 30%	0,594	-1,036	0,497	230,35
30% - 40%	0,793	-1,034	0,609	230,09
40% - 50%	0,997	-1,033	0,694	230,39
50% - 60%	1,208	-1,033	0,760	230,42
60% - 70%	1,403	-1,031	0,806	230,57
70% - 80%	1,595	-1,033	0,840	230,61
80% - 90%	1,805	-1,038	0,867	230,77
90% - 100%	1,934	-1,056	0,878	230,85
Capacitive (supply reactive power)				
Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ)	AC voltage [V]
0% - 10%	0,179	1,039	0,169	230,01
10% - 20%	0,390	1,040	0,351	230,28
20% - 30%	0,596	1,042	0,496	230,37
30% - 40%	0,804	1,045	0,610	230,24
40% - 50%	1,006	1,046	0,693	230,48
50% - 60%	1,206	1,047	0,755	230,31
60% - 70%	1,411	1,052	0,802	230,73
70% - 80%	1,593	1,054	0,834	230,51
80% - 90%	1,806	1,055	0,863	230,57
90% - 100%	2,009	1,061	0,884	230,87
Reactive power supply with set point Q=0				
Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ)	AC voltage [V]
0% - 10%	0,194	0,000	0,999	230,02
10% - 20%	0,400	0,003	0,999	230,12
20% - 30%	0,604	0,005	0,999	230,24
30% - 40%	0,809	0,006	0,999	230,35
40% - 50%	1,010	0,008	0,999	230,32
50% - 60%	1,216	0,010	0,999	230,39
60% - 70%	1,419	0,013	0,999	230,52
70% - 80%	1,618	0,014	0,999	230,71
80% - 90%	1,820	0,016	0,999	230,82
90% - 100%	2,016	0,017	0,999	230,92

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Diagram of inductive reactive power absorption





BUREAU

VERITAS

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Controllable reactive power

X1-3.3-S-D

Inductive (supply reactive power)

Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ)	DC power [W]
0% - 10%	0,292	-1,680	0,171	229,75
10% - 20%	0,628	-1,676	0,351	229,79
20% - 30%	0,961	-1,672	0,498	229,95
30% - 40%	1,294	-1,669	0,613	230,11
40% - 50%	1,625	-1,665	0,699	230,25
50% - 60%	1,955	-1,663	0,762	230,40
60% - 70%	2,288	-1,658	0,810	230,54
70% - 80%	2,610	-1,655	0,845	230,69
80% - 90%	2,927	-1,653	0,871	230,84
90% - 100%	3,202	-1,655	0,873	231,02

Capacitive (supply reactive power)

Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ)	DC power [W]
0% - 10%	0,296	1,667	0,175	229,83
10% - 20%	0,635	1,670	0,355	229,88
20% - 30%	0,971	1,673	0,502	230,06
30% - 40%	1,300	1,677	0,613	230,21
40% - 50%	1,629	1,680	0,696	230,41
50% - 60%	1,961	1,684	0,759	230,57
60% - 70%	2,283	1,686	0,804	230,70
70% - 80%	2,616	1,684	0,805	230,86
80% - 90%	2,910	1,685	0,805	230,86
90% - 100%	3,217	1,685	0,876	230,86

Reactive power supply with set point Q=0


Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ)	DC power [W]
0% - 10%	0,316	0,056	0,985	229,85
10% - 20%	0,652	0,050	0,997	230,04
20% - 30%	0,985	0,047	0,999	230,02
30% - 40%	1,319	0,046	0,999	230,19
40% - 50%	1,642	0,044	0,999	230,33
50% - 60%	1,962	0,046	0,999	230,48
60% - 70%	2,325	0,049	0,999	230,60
70% - 80%	2,660	-0,001	0,999	231,06
80% - 90%	2,941	0,001	0,999	231,27
90% - 100%	3,194	-0,054	0,999	231,09

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Diagram of inductive reactive power absorption



Q adjustment				
X1-2.0-S-D	Reactive power set point Q [Var]	Measured reactive power Q [Var]	Measured cos φ	Deviation compared to setpoint ΔQ / PN [%]
- Qmin	-1,000	-1,059	0,879	2,95
0	0	0,017	1,000	0,85
+ Qmax	1,000	1,061	0,884	3,05
Q adjustment				
X1-3.0-S-D	Reactive power set point Q [Var]	Measured reactive power Q [Var]	Measured cos φ	Deviation compared to setpoint ΔQ / PN [%]
- Qmin	-1,650	-1,657	0,873	0,21
0	0	-0,055	0,999	1,67
+ Qmax	1,650	1,684	0,877	1,03

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Standard curve Q(f)

X1-2.0-S-D

Qmin reactive power in accordance to standard characteristic curve Q=f(V)

P/Pn	Vac [V] Set point	P/Pn [%]	Vac [V] measured	Q [Var] measured	Q [Var] expected	ΔQ [%]
< 20%	1,07Vn	9,62	246,19	-0,15	$\approx 0 (< \pm 2.5\% P_n)$	0,01
< 20%	1,09Vn	9,58	250,74	-0,35	$\approx 0 (< \pm 2.5\% P_n)$	0,02
< 20%-30%	1,09Vn	29,97	250,73	-467,85	-0,5 Qmin	1,61
40%	1,09Vn	40,30	250,72	-478,75	-0,5 Qmin	1,06
50%	1,09Vn	50,44	250,74	-505,80	-0,5 Qmin	0,29
60%	1,09Vn	60,65	250,73	-475,65	-0,5 Qmin	1,22
70%	1,09Vn	70,69	250,71	-485,85	-0,5 Qmin	0,71
80%	1,09Vn	80,74	250,71	-501,45	-0,5 Qmin	0,07
90%	1,09Vn	90,83	250,72	-468,90	-0,5 Qmin	1,56
100%	1,09Vn	100,86	250,73	-502,90	-0,5 Qmin	0,15
100%	1,1Vn	100,51	253,04	-977,65	-Qmin	1,12
100%-10%	1,1Vn	8,86	253,04	-959,05	-Qmin	2,05
10% → ≤5%	1,1Vn	2,40	252,98	-1,40	$\approx 0 (< \pm 2.5\% P_n)$	0,07

Qmax reactive power in accordance to standard characteristic curve Q=f(V)

P/Pn	Vac [V] Set point	P/Pn [%]	Vac [V] measured	Q [Var] measured	Q [Var] expected	ΔQ [%]
< 20%	0,93Vn	9,66	213,92	-0,15	$\approx 0 (< \pm 2.5\% P_n)$	0,01
< 20%	0,91Vn	9,71	209,34	0,20	$\approx 0 (< \pm 2.5\% P_n)$	0,01
< 20%-30%	0,91Vn	30,19	209,48	525,20	-0,5 Qmin	1,26
40%	0,91Vn	40,30	209,35	530,80	-0,5 Qmin	1,54
50%	0,91Vn	50,40	209,36	530,80	-0,5 Qmin	1,54
60%	0,91Vn	60,41	209,37	530,50	-0,5 Qmin	1,53
70%	0,91Vn	70,51	209,38	529,75	-0,5 Qmin	1,49
80%	0,91Vn	80,42	209,28	536,50	-0,5 Qmin	1,83
90%	0,91Vn	90,55	209,26	540,75	-0,5 Qmin	2,04
100%	0,91Vn	97,83	209,36	537,95	-0,5 Qmin	1,90
100%	0,90Vn	87,23	207,07	1042,70	-Qmin	2,14
100%-10%	0,90Vn	8,87	207,02	1026,65	-Qmin	1,33
10% → ≤5%	0,90Vn	2,43	207,02	-0,55	$\approx 0 (< \pm 2.5\% P_n)$	0,03

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Standard curve Q(f)						
X1-3.3-S-D						
Qmin reactive power in accordance to standard characteristic curve Q=f(V)						
P/Pn	Vac [V] Set point	P/Pn [%]	Vac [V] measured	Q [Var] measured	Q [Var] expected	ΔQ [%]
< 20%	1,07Vn	9,70	246,12	59,20	$\approx 0 (< \pm 2.5\% P_n)$	1,79
< 20%	1,09Vn	9,66	250,60	58,95	$\approx 0 (< \pm 2.5\% P_n)$	1,79
< 20%-30%	1,09Vn	29,56	250,59	832,50	-0,5 Qmin	0,53
40%	1,09Vn	39,60	250,61	797,70	-0,5 Qmin	1,58
50%	1,09Vn	49,46	250,60	823,00	-0,5 Qmin	0,82
60%	1,09Vn	59,37	250,60	828,95	-0,5 Qmin	0,64
70%	1,09Vn	69,25	250,60	807,45	-0,5 Qmin	1,29
80%	1,09Vn	78,89	250,59	815,45	-0,5 Qmin	1,05
90%	1,09Vn	88,73	250,61	774,00	-0,5 Qmin	2,30
100%	1,09Vn	98,53	250,60	817,70	-0,5 Qmin	0,98
100%	1,1Vn	98,67	253,01	1663,20	-Qmin	1,12
100%-10%	1,1Vn	8,82	253,02	1627,95	-Qmin	2,18
10% \rightarrow \leq 5%	1,1Vn	2,56	253,01	64,75	$\approx 0 (< \pm 2.5\% P_n)$	1,96
Qmax reactive power in accordance to standard characteristic curve Q=f(V)						
P/Pn	Vac [V] Set point	P/Pn [%]	Vac [V] measured	Q [Var] measured	Q [Var] expected	ΔQ [%]
< 20%	0,93Vn	9,69	213,86	50,45	$\approx 0 (< \pm 2.5\% P_n)$	1,53
< 20%	0,91Vn	9,78	209,16	51,45	$\approx 0 (< \pm 2.5\% P_n)$	1,56
< 20%-30%	0,91Vn	29,70	209,17	917,10	-0,5 Qmin	2,03
40%	0,91Vn	39,67	209,17	931,20	-0,5 Qmin	2,46
50%	0,91Vn	49,49	209,17	927,65	-0,5 Qmin	2,35
60%	0,91Vn	59,36	209,16	926,15	-0,5 Qmin	2,31
70%	0,91Vn	69,08	209,17	876,95	-0,5 Qmin	0,82
80%	0,91Vn	79,09	209,17	872,50	-0,5 Qmin	0,68
90%	0,91Vn	88,81	209,17	845,00	-0,5 Qmin	-0,15
100%	0,91Vn	89,90	209,17	902,55	-0,5 Qmin	1,59
100%	0,90Vn	79,86	207,04	1673,30	-Qmin	-1,06
100%-10%	0,90Vn	9,02	207,03	1662,25	-Qmin	-1,14
10% \rightarrow \leq 5%	0,90Vn	2,50	207,04	55,65	$\approx 0 (< \pm 2.5\% P_n)$	-1,69

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Connection and starting to generate electrical power		
X1-2.0-S-D		
Voltage conditions		
a) Start up for voltage range	<84% Un for twice of observation time	>111% Un for twice of observation time
Connection:	No connection	No connection
Limit:	No connection allowed	
b) In voltage range at start-up	≥84% Un within twice setting observation time	≤111% Un within twice setting observation time
Reconnection time [s]	80	80
Limit:	Connected after setting observation time (≥60s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min. For recorded gradient see diagram below.	
c) In voltage range after voltage failure	≥84% Un for twice of setting observation time	≤111% Un for twice of setting observation time
Reconnection time [s]	81	80
Limit:	Reconnection after setting observation time (≥60s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min. For recorded gradient see diagram below.	
Frequency conditions		
d) Start up for frequency range	<47,45 Hz for twice of setting observation time	>50,15 Hz for twice of setting observation time
Connection:	No connection	No connection
Limit:	No connection allowed	
e) In frequency range at start-up	≥47,45 Hz within twice of setting observation time	≤51,15 Hz within twice of setting observation time
Reconnection time [s]	80	81
Limit:	Connected after setting delay time(≥60s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min. For recorded gradient see diagram below.	
f) In frequency range after frequency failure	≥47,45 Hz for twice of setting observation time	≤51,15 Hz for twice of setting observation time
Reconnection time [s]	80	82
Limit:	Reconnection after setting observation time (≥60s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min. For recorded gradient see diagram below.	

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Connection and starting to generate electrical power		
X1-3.3-S-D		
Voltage conditions		
a) Start up for voltage range	<84% Un for twice of observation time	>111% Un for twice of observation time
Connection:	No connection	No connection
Limit:	No connection allowed	
b) In voltage range at start-up	≥84% Un within twice setting observation time	≤111% Un within twice setting observation time
Reconnection time [s]	86	83
Limit:	Connected after setting observation time (≥60s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min. For recorded gradient see diagram below.	
c) In voltage range after voltage failure	≥84% Un for twice of setting observation time	≤111% Un for twice of setting observation time
Reconnection time [s]	85	86
Limit:	Reconnection after setting observation time (≥60s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min. For recorded gradient see diagram below.	
Frequency conditions		
d) Start up for frequency range	<47,45 Hz for twice of setting observation time	>50,15 Hz for twice of setting observation time
Connection:	No connection	No connection
Limit:	No connection allowed	
e) In frequency range at start-up	≥47,45 Hz within twice of setting observation time	≤51,15 Hz within twice of setting observation time
Reconnection time [s]	85	80
Limit:	Connected after setting delay time(≥60s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min. For recorded gradient see diagram below.	
f) In frequency range after frequency failure	≥47,45 Hz for twice of setting observation time	≤51,15 Hz for twice of setting observation time
Reconnection time [s]	85	78
Limit:	Reconnection after setting observation time (≥60s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min. For recorded gradient see diagram below.	

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Short-circuit current contribution					
Short-circuit current parameters					
X1-2.0-S-D					
For a directly coupled micro-generator			For a Inverter micro-generator		
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	I_p	N/A	20ms	159	3,02
Initial Value of aperiodic current	A	N/A	100ms	N/A	N/A
Initial symmetrical short-circuit current*	I_k	N/A	250ms	N/A	N/A
Decaying (aperiodic) component of short circuit current*	i_{DC}	N/A	500ms	N/A	N/A
Reactance/Resistance Ratio of source*	X/R	N/A	Time to trip	8,7 ms	
X1-3.3-S-D					
For a directly coupled micro-generator			For a Inverter micro-generator		
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	I_p	N/A	20ms	165	9,81
Initial Value of aperiodic current	A	N/A	100ms	N/A	N/A
Initial symmetrical short-circuit current*	I_k	N/A	250ms	N/A	N/A
Decaying (aperiodic) component of short circuit current*	i_{DC}	N/A	500ms	N/A	N/A
Reactance/Resistance Ratio of source*	X/R	N/A	Time to trip	0,38 ms	

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Power Quality. Harmonic current emission				
micro-generator		X1-1.1-S-D		
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN 61000-3-2, Class A [A]
1st	4,380	--	Phase 1	-
2nd	0,028	0,639	Phase 1	1,080
3rd	0,026	0,595	Phase 1	2,300
4th	0,003	0,068	Phase 1	0,430
5th	0,012	0,269	Phase 1	1,140
6th	0,001	0,030	Phase 1	0,300
7th	0,012	0,282	Phase 1	0,770
8th	0,001	0,026	Phase 1	0,230
9th	0,012	0,279	Phase 1	0,400
10th	0,001	0,024	Phase 1	0,184
11th	0,009	0,214	Phase 1	0,330
12th	0,002	0,036	Phase 1	0,153
13th	0,010	0,223	Phase 1	0,210
14th	0,001	0,020	Phase 1	0,131
15th	0,010	0,230	Phase 1	0,150
16th	0,001	0,023	Phase 1	0,115
17th	0,012	0,273	Phase 1	0,132
18th	0,002	0,036	Phase 1	0,102
19th	0,011	0,254	Phase 1	0,118
20th	0,001	0,022	Phase 1	0,092
21th	0,010	0,238	Phase 1	0,107
22th	0,001	0,023	Phase 1	0,084
23th	0,008	0,176	Phase 1	0,098
24th	0,001	0,028	Phase 1	0,077
25th	0,008	0,192	Phase 1	0,090
26th	0,001	0,019	Phase 1	0,071
27th	0,006	0,140	Phase 1	0,083
28th	0,000	0,011	Phase 1	0,066
29th	0,005	0,121	Phase 1	0,078
30th	0,000	0,008	Phase 1	0,061
31th	0,005	0,108	Phase 1	0,073
32th	0,000	0,007	Phase 1	0,058
33th	0,004	0,087	Phase 1	0,068
34th	0,000	0,009	Phase 1	0,054
35th	0,004	0,088	Phase 1	0,064
36th	0,000	0,007	Phase 1	0,051
37th	0,003	0,071	Phase 1	0,061
38th	0,000	0,011	Phase 1	0,048
39th	0,003	0,064	Phase 1	0,058
40th	0,001	0,014	Phase 1	0,046

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Power Quality. Harmonic current emission				
micro-generator		X1-1.5-S-D		
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN 61000-3-2, Class A [A]
1st	6,482	--	Phase 1	-
2nd	0,037	0,574	Phase 1	1,080
3rd	0,053	0,814	Phase 1	2,300
4th	0,005	0,070	Phase 1	0,430
5th	0,020	0,311	Phase 1	1,140
6th	0,001	0,021	Phase 1	0,300
7th	0,011	0,165	Phase 1	0,770
8th	0,001	0,016	Phase 1	0,230
9th	0,007	0,110	Phase 1	0,400
10th	0,001	0,014	Phase 1	0,184
11th	0,005	0,078	Phase 1	0,330
12th	0,002	0,025	Phase 1	0,153
13th	0,006	0,096	Phase 1	0,210
14th	0,001	0,012	Phase 1	0,131
15th	0,008	0,127	Phase 1	0,150
16th	0,001	0,011	Phase 1	0,115
17th	0,007	0,113	Phase 1	0,132
18th	0,002	0,034	Phase 1	0,102
19th	0,006	0,100	Phase 1	0,118
20th	0,001	0,016	Phase 1	0,092
21th	0,006	0,089	Phase 1	0,107
22th	0,002	0,028	Phase 1	0,084
23th	0,008	0,122	Phase 1	0,098
24th	0,001	0,022	Phase 1	0,077
25th	0,005	0,074	Phase 1	0,090
26th	0,002	0,023	Phase 1	0,071
27th	0,003	0,051	Phase 1	0,083
28th	0,001	0,012	Phase 1	0,066
29th	0,004	0,065	Phase 1	0,078
30th	0,001	0,009	Phase 1	0,061
31th	0,002	0,038	Phase 1	0,073
32th	0,000	0,007	Phase 1	0,058
33th	0,003	0,049	Phase 1	0,068
34th	0,000	0,007	Phase 1	0,054
35th	0,002	0,036	Phase 1	0,064
36th	0,001	0,011	Phase 1	0,051
37th	0,003	0,043	Phase 1	0,061
38th	0,001	0,009	Phase 1	0,048
39th	0,001	0,021	Phase 1	0,058
40th	0,001	0,014	Phase 1	0,046

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Power Quality. Harmonic current emission				
micro-generator		X1-2.0-S-D		
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN 61000-3-2, Class A [A]
1st	8,156	--	Phase 1	-
2nd	0,117	1,430	Phase 1	1,080
3rd	0,119	1,463	Phase 1	2,300
4th	0,009	0,112	Phase 1	0,430
5th	0,029	0,353	Phase 1	1,140
6th	0,002	0,025	Phase 1	0,300
7th	0,018	0,217	Phase 1	0,770
8th	0,003	0,031	Phase 1	0,230
9th	0,009	0,107	Phase 1	0,400
10th	0,003	0,032	Phase 1	0,184
11th	0,008	0,094	Phase 1	0,330
12th	0,003	0,034	Phase 1	0,153
13th	0,008	0,097	Phase 1	0,210
14th	0,003	0,031	Phase 1	0,131
15th	0,012	0,153	Phase 1	0,150
16th	0,002	0,021	Phase 1	0,115
17th	0,009	0,113	Phase 1	0,132
18th	0,004	0,044	Phase 1	0,102
19th	0,012	0,151	Phase 1	0,118
20th	0,002	0,030	Phase 1	0,092
21th	0,009	0,107	Phase 1	0,107
22th	0,003	0,042	Phase 1	0,084
23th	0,005	0,067	Phase 1	0,098
24th	0,002	0,024	Phase 1	0,077
25th	0,004	0,048	Phase 1	0,090
26th	0,002	0,024	Phase 1	0,071
27th	0,004	0,048	Phase 1	0,083
28th	0,002	0,030	Phase 1	0,066
29th	0,004	0,048	Phase 1	0,078
30th	0,001	0,010	Phase 1	0,061
31th	0,003	0,040	Phase 1	0,073
32th	0,001	0,015	Phase 1	0,058
33th	0,003	0,043	Phase 1	0,068
34th	0,001	0,011	Phase 1	0,054
35th	0,002	0,026	Phase 1	0,064
36th	0,001	0,013	Phase 1	0,051
37th	0,003	0,033	Phase 1	0,061
38th	0,001	0,015	Phase 1	0,048
39th	0,002	0,022	Phase 1	0,058
40th	0,002	0,020	Phase 1	0,046

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Power Quality. Harmonic current emission				
micro-generator		X1-2.5-S-D		
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN 61000-3-2, Class A [A]
1st	10,707	--	Phase 1	-
2nd	0,006	0,055	Phase 1	1,080
3rd	0,019	0,178	Phase 1	2,300
4th	0,003	0,025	Phase 1	0,430
5th	0,014	0,131	Phase 1	1,140
6th	0,001	0,009	Phase 1	0,300
7th	0,007	0,062	Phase 1	0,770
8th	0,002	0,015	Phase 1	0,230
9th	0,003	0,028	Phase 1	0,400
10th	0,001	0,013	Phase 1	0,184
11th	0,001	0,009	Phase 1	0,330
12th	0,002	0,018	Phase 1	0,153
13th	0,005	0,045	Phase 1	0,210
14th	0,001	0,010	Phase 1	0,131
15th	0,007	0,062	Phase 1	0,150
16th	0,001	0,013	Phase 1	0,115
17th	0,010	0,098	Phase 1	0,132
18th	0,003	0,027	Phase 1	0,102
19th	0,004	0,035	Phase 1	0,118
20th	0,001	0,012	Phase 1	0,092
21th	0,004	0,039	Phase 1	0,107
22th	0,002	0,021	Phase 1	0,084
23th	0,006	0,053	Phase 1	0,098
24th	0,001	0,013	Phase 1	0,077
25th	0,004	0,040	Phase 1	0,090
26th	0,002	0,020	Phase 1	0,071
27th	0,004	0,039	Phase 1	0,083
28th	0,002	0,023	Phase 1	0,066
29th	0,005	0,047	Phase 1	0,078
30th	0,003	0,025	Phase 1	0,061
31th	0,004	0,036	Phase 1	0,073
32th	0,001	0,011	Phase 1	0,058
33th	0,004	0,042	Phase 1	0,068
34th	0,001	0,011	Phase 1	0,054
35th	0,003	0,031	Phase 1	0,064
36th	0,001	0,009	Phase 1	0,051
37th	0,004	0,038	Phase 1	0,061
38th	0,001	0,009	Phase 1	0,048
39th	0,003	0,030	Phase 1	0,058
40th	0,001	0,009	Phase 1	0,046

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Power Quality. Harmonic current emission				
micro-generator		X1-3.0-S-D		
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN 61000-3-2, Class A [A]
1st	12,838	--	Phase 1	-
2nd	0,007	0,051	Phase 1	1,080
3rd	0,028	0,218	Phase 1	2,300
4th	0,006	0,043	Phase 1	0,430
5th	0,019	0,146	Phase 1	1,140
6th	0,001	0,011	Phase 1	0,300
7th	0,006	0,048	Phase 1	0,770
8th	0,002	0,015	Phase 1	0,230
9th	0,001	0,010	Phase 1	0,400
10th	0,002	0,014	Phase 1	0,184
11th	0,004	0,029	Phase 1	0,330
12th	0,002	0,016	Phase 1	0,153
13th	0,003	0,025	Phase 1	0,210
14th	0,001	0,009	Phase 1	0,131
15th	0,002	0,018	Phase 1	0,150
16th	0,001	0,010	Phase 1	0,115
17th	0,005	0,042	Phase 1	0,132
18th	0,002	0,017	Phase 1	0,102
19th	0,006	0,048	Phase 1	0,118
20th	0,001	0,010	Phase 1	0,092
21th	0,006	0,047	Phase 1	0,107
22th	0,002	0,019	Phase 1	0,084
23th	0,007	0,057	Phase 1	0,098
24th	0,002	0,012	Phase 1	0,077
25th	0,006	0,044	Phase 1	0,090
26th	0,002	0,017	Phase 1	0,071
27th	0,006	0,043	Phase 1	0,083
28th	0,004	0,029	Phase 1	0,066
29th	0,006	0,044	Phase 1	0,078
30th	0,003	0,020	Phase 1	0,061
31th	0,005	0,040	Phase 1	0,073
32th	0,002	0,013	Phase 1	0,058
33th	0,005	0,039	Phase 1	0,068
34th	0,002	0,013	Phase 1	0,054
35th	0,003	0,027	Phase 1	0,064
36th	0,001	0,011	Phase 1	0,051
37th	0,005	0,036	Phase 1	0,061
38th	0,001	0,010	Phase 1	0,048
39th	0,003	0,027	Phase 1	0,058
40th	0,001	0,010	Phase 1	0,046

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Power Quality. Harmonic current emission				
micro-generator		X1-3.3-S-D		
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN 61000-3-2, Class A [A]
1st	13,883	--	Phase 1	-
2nd	0,006	0,046	Phase 1	1,080
3rd	0,040	0,288	Phase 1	2,300
4th	0,007	0,051	Phase 1	0,430
5th	0,017	0,123	Phase 1	1,140
6th	0,001	0,010	Phase 1	0,300
7th	0,005	0,034	Phase 1	0,770
8th	0,002	0,016	Phase 1	0,230
9th	0,001	0,009	Phase 1	0,400
10th	0,002	0,014	Phase 1	0,184
11th	0,004	0,031	Phase 1	0,330
12th	0,002	0,013	Phase 1	0,153
13th	0,004	0,030	Phase 1	0,210
14th	0,001	0,008	Phase 1	0,131
15th	0,004	0,026	Phase 1	0,150
16th	0,001	0,010	Phase 1	0,115
17th	0,006	0,043	Phase 1	0,132
18th	0,002	0,018	Phase 1	0,102
19th	0,006	0,046	Phase 1	0,118
20th	0,001	0,009	Phase 1	0,092
21th	0,007	0,053	Phase 1	0,107
22th	0,002	0,014	Phase 1	0,084
23th	0,008	0,059	Phase 1	0,098
24th	0,002	0,012	Phase 1	0,077
25th	0,007	0,051	Phase 1	0,090
26th	0,002	0,014	Phase 1	0,071
27th	0,007	0,049	Phase 1	0,083
28th	0,005	0,035	Phase 1	0,066
29th	0,005	0,036	Phase 1	0,078
30th	0,002	0,017	Phase 1	0,061
31th	0,006	0,047	Phase 1	0,073
32th	0,002	0,014	Phase 1	0,058
33th	0,006	0,042	Phase 1	0,068
34th	0,003	0,023	Phase 1	0,054
35th	0,006	0,043	Phase 1	0,064
36th	0,004	0,025	Phase 1	0,051
37th	0,004	0,029	Phase 1	0,061
38th	0,003	0,019	Phase 1	0,048
39th	0,004	0,030	Phase 1	0,058
40th	0,001	0,010	Phase 1	0,046

Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. SXP-16JY2393FTSP

Voltage fluctuation and Flicker.					
X1-2.0-S-D	Maximum permissible flicker and voltage fluctuation as per EN 61000-3-3				
Value	Pst	Plt 2 hours	d(t) _{500ms}	dc	dmax
Limit	1,0	0,65	3,3%	3,3%	4%
Test value	0,08	0,08	0,00%	0,43%	0,48%

Voltage fluctuation and Flicker.					
X1-3.3-S-D	Maximum permissible flicker and voltage fluctuation as per EN 61000-3-3				
Value	Pst	Plt 2 hours	d(t) _{500ms}	dc	dmax
Limit	1,0	0,65	3,3%	3,3%	4%
Test value	0,18	0,16	0,00%	0,88%	0,89%

DC-Injection.				
X1-1.1-S-D				
Protection limit	Tested at four power levels limit 0,5% of IAC _{nom}			
Output power	~20%	~50%	75%	~100%
Max. test value (phase L1) [mA]	14,3	20,4	20,2	12,2
X1-1.5-S-D				
Protection limit	Tested at four power levels limit 0,5% of IAC _{nom}			
Output power	~20%	~50%	75%	~100%
Max. test value (phase L1) [mA]	12,3	11,1	8,5	6,5
X1-2.0-S-D				
Protection limit	Tested at four power levels limit 0,5% of IAC _{nom}			
Output power	~20%	~50%	75%	~100%
Max. test value (phase L1) [mA]	6,6	8,6	-3,0	15,7
X1-2.5-S-D				
Protection limit	Tested at four power levels limit 0,5% of IAC _{nom}			
Output power	~20%	~50%	75%	~100%
Max. test value (phase L1) [mA]	16,5	11,8	-5,5	-14,0
X1-3.0-S-D				
Protection limit	Tested at four power levels limit 0,5% of IAC _{nom}			
Output power	~20%	~50%	75%	~100%
Max. test value (phase L1) [mA]	16,4	11,7	-9,2	-17,1
X1-3.3-S-D				
Protection limit	Tested at four power levels limit 0,5% of IAC _{nom}			
Output power	~20%	~50%	75%	~100%
Max. test value (phase L1) [mA]	14,8	7,7	-10,4	3,7