



**BUREAU  
VERITAS**

# Certificate of compliance

**Applicant:** SolaX power Co.,Ltd.  
Room 220,West Building A,National University Science and  
Technology Park of Zhejiang University 525,Xixi Rd  
China

**Product:** Photovoltaic (PV) Inverter

**Model:** SK-TL3000 C/E/R  
SK-TL3700 C/E/R  
SK-TL5000 C/E/R  
SK-SU3000 C/E  
SK-SU3700 C/E  
SK-SU5000 C/E

## Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with C10/11 – 06.2012 Appendix 4 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

## Applied rules and standards:

### C10/11:2012-06

Specific technical requirements for generator in parallel operation with the distribution network

### DIN V VDE V 0126-1-1/A1:2012-02

Automatic disconnection device between a generator and the public low-voltage grid; Amendment 1

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** SXP-14NO1486FTSP-C10-11

**Certificate number:** U15-0229

**Date of issue:** 2015-06-18

## Certification body

Dieter Zitzmann



Deutsche  
Akkreditierungsstelle  
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH  
Accredited according to EN 45011 - ISO / IEC Guide 65