



BV LCIE
 CHINA N°1666AS07SXP21405-N1
 Number
 This attestation replaces the attestation
 N°1666AS07SXP21405
 which was cancelled

ATTESTATION of conformity with European Directives

Product: **Grid-tied photovoltaic inverter**
Reference **X1-0.7-S-N, X1-0.7-S-D, X1-1.1-S-D, X1-1.1-S-N, X1-1.5-S-D, X1-1.5-S-N, X1-2.0-S-D, X1-2.0-S-N, X1-2.5-S-D, X1-2.5-S-N, X1-3.0-S-D, X1-3.0-S-N, X1-3.3-S-D, X1-3.3-S-N.**
Issued to **SolaX Power Network Technology (Zhe jiang) Co., Ltd.**
Address **No. 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing District 311500, Tonglu City, Zhejiang Province, People's Republic of China**
Manufacturer **SolaX Power Network Technology (Zhe jiang) Co., Ltd.**
Technical characteristics **See Next Page**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 62109-1: 2010 EN 62109-2: 2011	SXP-16JA0323FTSP-1	30/01/2018
	SXP-16JA0323FTSP-1-A1	
	SXP-16JA0323FTSP-2	30/01/2018
	SXP-16JA0323FTSP-2-A1	

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
 The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China),), January 31st, 2018.



Dio Zhang
 Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
 Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
 必维欧亚电气技术咨询服务(上海)有限公司
 Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
 CaoHejing Songjiang High-Tech Park,
 Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
 Fax: +86 21 6195 7001
 Email: contact@cn.bureauveritas.com



LCIE

BV LCIE
CHINA N° 1666AS07SXP21405-N1
Number
This attestation replaces the attestation
N°1666AS07SXP21405
which was cancelled

Model / Type :	X1-0.7-S-D X1-0.7-S-N	X1-1.1-S-D X1-1.1-S-N	X1-1.5-S-D X1-1.5-S-N
MPP DC voltage range [V] :	55-380	70-380	70-380
Input DC voltage range [V] :	55-400	70-400	70-400
Input DC current [A] :	10,0	10,0	10,0
Output AC voltage [V] :	220/230/240 Vac, 50/60Hz	220/230/240 Vac, 50/60Hz	220/230/240 Vac, 50/60Hz
Max.Output AC current [A] :	3,5	5,5	7,5
Output power [VA] :	700	1100	1500

Model / Type :	X1-2.0-S-D X1-2.0-S-N	X1-2.5-S-D X1-2.5-S-N	X1-3.0-S-D X1-3.0-S-N
MPP DC voltage range [V] :	70-380	100-580	100-580
Input DC voltage range [V] :	70-400	100-600	100-600
Input DC current [A] :	10,0	10,0(Max)	10,0(Max)
Output AC voltage [V] :	220/230/240 Vac, 50/60Hz	220/230/240 Vac, 50/60Hz	220/230/240 Vac, 50/60Hz
Max.Output AC current [A] :	9,5	12	14
Output power [VA] :	2000	2500	3000

Model / Type :	X1-3.3-S-D X1-3.3-S-N
MPP DC voltage range [V] :	100-580
Input DC voltage range [V] :	100-600
Input DC current [A] :	10,0(Max)
Output AC voltage [V] :	220/230/240 Vac, 50/60Hz
Max.Output AC current [A] :	15
Output power [VA] :	3300

Shanghai (P.R. China), , January 31st, 2018.



Dio Zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有
限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com