



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA181578

Certificate Holder: SolaX Power Network Technology (Zhejiang) Co., Ltd
No. 288 Shizhu Road,
Tonglu Economic Development Zone,
Dongxing District 311500, Tonglu City,
Zhejiang Province
P.R. China

Class Description: Non-Declared
Product Description: Grid-connected Photovoltaic Inverter

Brand Name:



Model No.:

X3-30.0-T-D

Markings:

Input: Max 1000Vdc, rated input voltage: 640Vdc,
MPP voltage range: 280-950Vdc, Max 34A/34A
Isc: 48A/48A, Max 20kW/20kW
Output: 400/230V~ 3N~ 50/60Hz 3x45A,
Max 3x48A, Max 30000VA

Standard:

IEC 62109-1 Ed 1.0
IEC 62109-2 Ed 1.0
AS/NZS 4777.2:2015

Conditions:

Nil

Certification Mark: SAA181578 or RCM

Date First Registered: 11 June 2018

Date of Expiry: 11 June 2023

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 12-06-18 181578/1a
Marking corrected