



A P P R O V A L S ®

## Certificate of Suitability

\* Addendum \*

**Certificate No.:** SAA181578

**Date of Issue:** 11 June 2018

**Class Description:** Non-Declared

**Product Description:** Grid-connected Photovoltaic Inverter

<b>Additional Models</b>	<b>Description</b>
X3-30.0-T-N	Similar to X3-30.0-T-D except for deletion of DC switch.
X3-36.0-T-D	Similar to X3-30.0-T-D except rated: Input: Max 1000Vdc, rated input voltage: 640Vdc, MPP voltage range: 280-950Vdc, Max 34A/34A Isc: 48A/48A, Max 23kW/23kW Output: 480V~ 3N~ 50/60Hz 3x45A, Max 3x48A, Max 36000VA
X3-36.0-T-N	Similar to X3-36.0-T-D except for deletion of DC switch.

*R.A. Hill*

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 12-06-18 181578/2a  
Description corrected