



BV LCIE  
CHINA  
Number

N° 1666AS07SXP21405-N2

This attestation replaces the attestation  
N°1766AS01SXP23426  
Which was cancelled

## ATTESTATION of conformity with European Directives

*Product:* Grid-connected photovoltaic inverter  
*Reference:* X1-3.0-T-D,X1-3.0-T-N,X1-3.3-T-D,X1-3.3-T-N,X1-3.6-T-D,  
X1-3.6-T-N,X1-4.2-T-D,X1-4.2-T-N,X1-5.0-T-D,X1-5.0-T-N,  
X1-5.3-T-D,X1-5.3-T-N., X1-5.98-T-D,X1-5.98-T-N.  
*Issued to:* SolaX Power Network Technology (Zhe jiang) Co. , Ltd.  
*Address:* No. 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing  
District 311500, Tonglu City, Zhejiang Province, People's Republic of  
China  
*Manufacturer:* SolaX Power Network Technology (Zhe jiang) Co. , Ltd.  
*Technical characteristics:* See Next Page

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 62109-1: 2010	SXP-16JA0323FTSP-1-R1	21/11/2018
EN 62109-2: 2011	SXP-16JA0323FTSP-2-R1	21/11/2018

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), , November 21<sup>th</sup>, 2018.



Harvey Wang  
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA  
必维欧亚电气技术咨询服务(上海)有  
限公司

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)

Version 3/2016.02.19



LCIE

BV LCIE  
CHINA  
Number

N° 1666AS07SXP21405-N2

This attestation replaces the attestation  
N°1766AS01SXP23426  
Which was cancelled

<b>Model / Type</b> .....	X1-3.0-T-D, X1-3.0-T-N	X1-3.3-T-D, X1-3.3-T-N	X1-3.6-T-D, X1-3.6-T-N
<b>Ratings</b> .....	See below	See below	See below
MPP DC voltage range [V] .....	125-580	125-580	125-580
Input DC voltage range [V] .....	125-600	125-600	125-600
Input DC current [A] .....	12/12	12/12	12/12
Output AC voltage [V] .....	220/230/240 Vac, 50/60Hz	220/230/240 Vac, 50/60Hz	220/230/240 Vac, 50/60Hz
Max.Output AC current [A] .....	14	15	16
Output power [VA] .....	3000	3300	3680

<b>Model / Type</b> .....	X1-4.2-T-D, X1-4.2-T-N	X1-5.0-T-D, X1-5.0-T-N, X1-5.3-T-D, X1-5.3-T-N., X1-5.98-T-D, X1-5.98-T-N.
<b>Ratings</b> .....	See below	See below
MPP DC voltage range [V] .....	125-580	125-580
Input DC voltage range [V] .....	125-600	125-600
Input DC current [A] .....	12/12	12/12
Output AC voltage [V] .....	220/230/240 Vac, 50/60Hz	220/230/240 Vac, 50/60Hz
Max.Output AC current [A] .....	19	21
Output power [VA] .....	4200	4600

Shanghai (P.R. China), ), November 21<sup>th</sup>, 2018.



Harvey Wang  
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA  
必维欧亚电气技术咨询服务(上海)有  
限公司  
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)