



APPROVALS®

Certificate of Suitability

Addendum

Certificate No.: SAA201525

Date of Issue: 20 July 2020

Regulatory Definition: Non-Prescribed

Product Description: PV Inverter (Grid-tied Photovoltaic Inverter)

General Modification:

For model X3-50K-TL:-
Software version: 600101

Additional Models	Trade Name	Rating/Marking	Description
X3-60K-TL	SOLAXPOWER	Input: MPPT Voltage range: 540-850Vdc, Max 1100Vdc, Max 33A/33A/33A/33A, Isc: 42A/42A/42A/42A Output: 380/400/415V~ 50/60Hz, 92A 60000W 60000VA Class I, IP65, -25°C to +60°C	Software version: 600101

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 23-07-20 201525/2a
Rating corrected