



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA201525

Certificate Holder: SolaX Power Network Technology (Zhejiang) Co., Ltd
No. 288 Shizhu Road,
Tonglu Economic Development Zone,
Dongxing District 311500, Tonglu City,
Zhejiang Province
P.R. China

Regulatory Definition: Non-Prescribed
Product Description: PV Inverter (Grid-tied Photovoltaic Inverter)
Trade Name: SOLAXPOWER
Model No.: X3-50K-TL
Rating/Marking: Input: MPPT Voltage range: 540-850Vdc,
Max. 1100Vdc, Max. 33A/33A/22A/22A,
Isc: 42A/42A/28A/28A
Output: 380/400/415V~ 50/60Hz,
83A 50000W 55000VA
Class I, IP65, -25°C to +60°C

Standard: AS/NZS 4777.2:2015
IEC 62109-1 Ed 1.0
IEC 62109-2 Ed 1.0

Conditions: Nil

Certification Mark: RCM and SAA201525

Date First Registered: 20 July 2020

Date of Expiry: 20 July 2025

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 20-07-20 201525/1

www.jas-anz.org/register