



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA172231

Date of Issue: 18 September 2017

Class Description: Non-Declared

Product Description: Grid-Connected Photovoltaic Inverter

Additional Models	Description
X1-Hybrid-3.0-D-I	Similar to X1-Hybrid-5.0-D-I except rated PV input: Max. DC power: 4000W; AC input: max. continuous AC current: 14.4A; AC output: max. continuous AC current: 14.4A, nominal AC apparent power 3000VA; EPS output: max. apparent power: 4000VA EPS rated current: 17.4A
X1-Hybrid-5.0-D-C	Similar to X1-Hybrid-5.0-D-E except for deletion of Eps output mode
X1-Hybrid-4.6-D-C	Similar to X1-Hybrid-5.0-D-C except rated AC input: max. continuous AC current: 21A; AC output: max. continuous AC current: 21A, nominal AC apparent power 4600VA
X1-Hybrid-3.7-D-C	Similar to X1-Hybrid-5.0-D-C except rated PV input: Max. DC power: 5000W; AC input: max. continuous AC current: 16A; AC output: max. continuous AC current: 16A, nominal AC apparent power 3680VA; EPS output: max. apparent power: 4000VA.
X1-Hybrid-3.0-D-C	Similar to X1-Hybrid-5.0-D-C except rated PV input: Max. DC power: 4000W; AC input: max. continuous AC current: 14.4A; AC output: max. continuous AC current: 14.4A, nominal AC apparent power 3000VA; EPS output: max. apparent power: 4000VA.
X1-Hybrid-5.0-N-E	Similar to X1-Hybrid-5.0-N-E except for deletion of DC switch.
X1-Hybrid-4.6-N-E	Similar to X1-Hybrid-4.6-N-E except for deletion of DC switch.
X1-Hybrid-3.7-N-E	Similar to X1-Hybrid-3.7-N-E except for deletion of DC switch.
X1-Hybrid-3.0-N-E	Similar to X1-Hybrid-3.0-N-E except for deletion of DC switch.
X1-Hybrid-5.0-N-I	Similar to X1-Hybrid-5.0-N-I except for deletion of DC switch.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 18-09-17 172231/3