



BV LCIE
CHINA
Number N°1966AS05SXP31636-N1

This attestation replaces the attestation
N°1966AS05SXP31636
which was cancelled

ATTESTATION of conformity with European Directives



Product: PV inverter (Grid-tied photovoltaic inverter)
Reference: X1-0.7-S-D(L), X1-1.1-S-D(L), X1-1.5-S-D(L), X1-2.0-S-D(L),
X1-0.7-S-N(L), X1-1.1-S-N(L), X1-1.5-S-N(L), X1-2.0-S-N(L),
X1-0.7-S-D(O), X1-1.1-S-D(O), X1-1.5-S-D(O), X1-2.0-S-D(O),
X1-0.7-S-N(O), X1-1.1-S-N(O), X1-1.5-S-N(O), X1-2.0-S-N(O)
Issued to: SolaX Power Network Technology (Zhe jiang) Co., Ltd.
Address: No. 288 Shizhu Road, Tonglu Economic Development Zone, Dongxing
District 311500, Tonglu City, Zhejiang Province, People's Republic of
China
Manufacturer: SolaX Power Network Technology (Zhe jiang) Co., Ltd.
Technical characteristics: See Next Page

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 62109-1: 2010	SXP-19MA1487FCSHP-1-R1	05/07/2020
EN 62109-2: 2011	SXP-19MA1487FCSHP-2-R1	05/07/2020

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China),), July 22nd, 2020.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有
限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



LCIE

BV LCIE
 CHINA N°1766AS11SXP26545-N1
 Number
 This attestation replaces the attestation
 N°1766AS11SXP26545
 which was cancelled

Model / Type.....	X1-0.7-S-D(L) X1-0.7-S-N(L) X1-0.7-S-D(O) X1-0.7-S-N(O)	X1-1.1-S-D(L) X1-1.1-S-N(L) X1-1.1-S-D(O) X1-1.1-S-N(O)	X1-1.5-S-D(L) X1-1.5-S-N(L) X1-1.5-S-D(O) X1-1.5-S-N(O)	X1-2.0-S-D(L) X1-2.0-S-N(L) X1-2.0-S-D(O) X1-2.0-S-N(O)
MPP DC voltage range [V].....	55-380			
MAX Input DC voltage [V].....	400			
Max Input DC current [A]..	12			
Output AC voltage [V]	220/230/240V, 50/60Hz			
Max.Output AC current [A].....	3,3	5,3	7,2	9,6
Output power [VA].....	700(Rated) 770(Max.)	1100(Rated) 1210(Max.)	1500(Rated) 1650(Max.)	2000(Rated) 2200(Max.)

Shanghai (P.R. China),), July 22nd , 2020.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
 Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
 必维欧亚电气技术咨询服务(上海)有
 限公司
 Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
 CaoHejing Songjiang High-Tech Park,
 Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
 Fax: +86 21 6195 7001
 Email: contact@cn.bureauveritas.com